


## CARRIER CUBE UNIT



**BASED ON A REVIEW AND ANALYSIS THE FOLLOWING UNITS CONFORMS TO THE 2014 FLORIDA BUILDING CODE AND THE ASCE 7-10 WIND ANALYSIS CODE. SEE ENCLOSED ANCHORING DETAIL REQUIREMENT AS SPECIFIED IN SECTION 1620 , HIGH VELOCITY HURRICANE ZONES- WIND LOADS FOR MAX WIND SPEED OF 180 MPH AND MAX HEIGHT OF 60 FEET.**

CARRIER AIR CONDITIONER MODEL LIST FOR UTC "CUBE STYLE BASE PAN UNITS"		
UNITS UP TO 39" HIGH FOR 180 MPH WIND VELOCITY WITH A MAXIMUM BUILDING HEIGHT OF 60' EXPOSURE "D"	UNITS OVER 39" HIGH TO 44" HIGH FOR 180 MPH WIND VELOCITY WITH A MAXIMUM BUILDING HEIGHT OF 60' EXPOSURE "D"	UNITS OVER 44" HIGH TO 48" HIGH FOR 180 MPH WIND VELOCITY WITH A MAXIMUM BUILDING HEIGHT OF 60' EXPOSURE "C"
PA13NR (1.5-3.5 ton, 5 ton)	PA13NR (4 ton)	
CA13 (all tonnages)		
CA16 (1.5 -4 Ton)		CA16 (5-Ton)
24ABB3 (all tonnages)		
24ABB3C (all tonnages)		
24ABC6 (1.5 thru 4 Ton)		24ABC6 (5 Ton)
24ACB3 (all tonnages)		
24ACC6 (1.5-4 Ton)		24ACC6(5 Ton)
24ACB7 (2-4 Ton)		24ACB7 (5 Ton)
24ANB6 (1.5-3 Ton)	24ANB6 (3.5-4 Ton)	24ANB6 (5 Ton)
	24ANB7 (4 Ton)	
24ANB7 (2-3 Ton)	24ANB7 (5 Ton, series 1)	24ANB7 (5 Ton, series 0)
24ANB1 (2 -3,4 ,5 Ton, series 1)		24ANB1(2 -3,4 ,5 Ton, series 1)
24ANB136 (3 ton)	24ANB148 (4 ton)	24ANB160 (5 ton)

CARRIER HEAT PUMP MODEL LIST FOR UTC "CUBE STYLE BASE PAN UNITS"		
UNITS UP TO 39" HIGH FOR 180 MPH WIND VELOCITY WITH A MAXIMUM BUILDING HEIGHT OF 60' EXPOSURE "D"	UNITS OVER 39" HIGH TO 44" HIGH FOR 180 MPH WIND VELOCITY WITH A MAXIMUM BUILDING HEIGHT OF 50' EXPOSURE "D"	UNITS OVER 44" HIGH TO 48" HIGH FOR 180 MPH WIND VELOCITY WITH A MAXIMUM BUILDING HEIGHT OF 60' EXPOSURE "C"
PH13NR (1.5-4 ton)		PH13NR (5 ton)
CH13 (all tonnages)		
25HBB3 (all tonnages)		
25HBB3C (all tonnages)		
25HBC3 (all tonnages)		
25HBC5 (all tonnages)		
25HCD3 (all tonnages)		
25HCD4 (all tonnages)		
25HCC5 (all tonnages)		
25HCB6 (all tonnages)		25HCB6 (5 ton)
25HNB5 (1.5-4 ton)	25HNB5 (5 ton)	
25HNB5 (2-3.5 ton)	25HNB5 (4 ton)	
	25HNB6 (2-4 ton)	25HNB6 (5 ton)
		25HNB9 (2 ton series 0)
	25HNB9 (2 ton series 1)	25HNB9 (3-5 ton)
		25VNA0 (all tonnages)

**NOTE: ALL OF THE WIND RESISTING EXTERIOR PANELS, INDIVIDUALLY MEET OR EXCEED THEIR CAPACITY TO RESIST THE DESIGN WIND LOADS AS STATED IN THE CALCULATIONS AS REQUIRED BY THE FLORIDA STATE BUILDING CODE 2014. DUE TO THE INDETERMINENT NATURE OF THESE UNITS, DISTORTION AND DEFLECTION CANNOT BE ACCURATELY EVALUATED, BUT WITH DIAPHRAGM ACTION OF EXTERNAL COMPONENTS AND INTERNAL STIFFENERS, THE BASE UNIT HAS THE CAPACITY TO WITHSTAND THESE FORCES WITH INDIVIDUAL EXTERNAL PARTS BEING CONTAINED. YEARLY INSPECTIONS OR DURING EQUIPMENT MAINTENANCE, ALL TECH SCREWS, CABINET COMPONENTS, CLIPS AND ANCHOR BOLTS ARE TO BE VERIFIED BY THE A/C CONTRACTOR. ALL DAMAGED CABINET COMPONENTS, LOOSE, CORRODED, BROKEN TECH SCREWS OR ANCHOR BOLTS SHALL BE REPLACED TO ENSURE STRUCTURAL INTEGRITY FOR HURRICANE WIND FORCES**

<b>S-1</b>	Job No: 15-18	JOB NAME:	<b>CARRIER CUBE UNIT</b>	 <b>ROBERT E. SAMARA P.E., P.A.</b> email: samara@ppsenginc.com Consulting Engineers Structural PE # 19649
	Date: 09-11-2015			
	Chk'd By: R. Samara	TITLE:	4675 PONCE de LEON BLVD, #303 CORAL GABLES, FL 33146 Ph: 305-662-1916 Fax: 305-662-2491	
	Drawn By: A. Barnett	<b>MODELS LIST</b>		



**GENERAL NOTES**


1. SECTION PROPERTIES WERE DERIVED BY THE MANUFACTURER, SEE COMPONENT (PARTS) DRAWINGS BY UTC.
2. MAXIMUM UNIT WIND DESIGN BY VISUAL COMPARISONS OF MODELS IN EACH GROUP IS USED FOR THE ANALYSIS.
3. ALL UNIT COMPONENT (PARTS) ATTACHMENT TO EACH OTHER HAVE A MINIMUM OF (3) 10-16 TECH SCREWS PROVIDING A CAPACITY OF 2,545 LBS IN SHEAR (S.F.=3)

USE TD042 - 2"x4", 15 ga.  
STEEL TIE DOWN CLIPS,  
BY BMP INT. INC  
(G-90 GALV) AS SHOWN.  
PRODUCT APPROVAL  
FL#14234R3  
SEE DETAIL.

(2) #12-14 x 1" LG (HM#3) HILTI KLIK-FLEX  
SELF DRILLING STEEL SCREW W/ WASHERS

FOR CONCRETE FOUNDATION ATTACHMENT USE:  
 (2) 1/4" x 2 1/4" LG HEX HEAD STAINLESS STEEL BUILDDEX  
 TAPCON STEEL SCREWS (SHW4-214) AND  
 5/8" STAINLESS STEEL WASHERS OR  
 (2) 1/4" x 2 1/4" LG HEX HEAD BLUE COATED BUILDDEX  
 TAPCON SCREWS (HW4-214) AND 5/8" STAINLESS  
 STEEL WASHERS OR  
 (2) 1/4" x 3" LG POWERS WEDGE BOLT  
 HEAVY DUTY CONCRETE ANCHORS.

<b>S-2</b>	Job No: 15-18	JOB NAME: CUBE UNIT	 <b>ROBERT E. SAMARA P.E., P.A.</b> email: samara@ppsenginc.com Consulting Engineers Structural PE # 19649  675 PONCE de LEON BLVD, #303 CORAL GABLES, FL 33146 Ph: 305-662-1916 Fax: 305-662-2491
	Date: 09-11-2015	TITLE: CLIP AND ATTACHMENT LOCATION PLAN	
	Chk'd By: R. Samara		
	Drawn By: A. Barnett		



**GENERAL NOTES**


1. SECTION PROPERTIES WERE DERIVED BY THE MANUFACTURER, SEE COMPONENT (PARTS) DRAWINGS BY UTC.
2. MAXIMUM UNIT WIND DESIGN BY VISUAL COMPARISONS OF MODELS IN EACH GROUP IS USED FOR THE ANALYSIS.
3. ALL UNIT COMPONENT (PARTS) ATTACHMENT TO EACH OTHER HAVE A MINIMUM OF (3) 10-16 TECH SCREWS PROVIDING A CAPACITY OF 2595 LBS IN SHEAR (S.F.=3)

USE TDO42 - 2"X4", 15 ga.  
STEEL TIE DOWN CLIPS,  
BY BMP INT. INC  
(G-90 GALV) AS SHOWN,  
PRODUCT APPROVAL  
FL#14239R3  
SEE DETAIL.

(2) #12-14 x 1" Lg  
(HM#3) HILTI Kwik-FLEX  
SELF DRILLING STEEL  
SCREW W/ WASHERS

USE TDO42 - 2" X4", 15 ga.  
STEEL TIE DOWN CLIPS,  
BY BMP INT. INC  
(G-90 GALV) AS SHOWN,  
PRODUCT APPROVAL  
FL#14239R3

(2) SS 1/4"φ x 1-1/2" Lg  
THRU BOLTS W/ SS WASHERS




CLIP DETAIL

ALUM. STAND RAIL  
(BY OTHERS)

ALUM. STAND RAIL  
(BY OTHERS)

BASE PAN  
(.045" MIN THICK.)

S-3	Job No:	15-18	JOB NAME:	CUBE UNIT	 <b>ROBERT E. SAMARA P.E., P.A.</b> email: samara@ppsenglnc.com Consulting Engineers Structural PE # 19649
	Date:	09-11-2015	TITLE:	CLIP AND ATTACHMENT LOCATION PLAN (FOR ALUM STAND)	
	Chk'd By:	R. Samara			
	Drawn By:	A. Barnett			
		4675 PONCE de LEON BLVD, #303 CORAL GABLES, FL 33146 Ph: 305-662-1916 Fax: 305-662-2491			



**GENERAL NOTES**

1. SECTION PROPERTIES WERE DERIVED BY THE MANUFACTURER, SEE COMPONENT (PARTS) DRAWINGS BY UTC.
2. MAXIMUM UNIT WIND DESIGN BY VISUAL COMPARISONS OF MODELS IN EACH GROUP IS USED FOR THE ANALYSIS.
3. ALL UNIT COMPONENT (PARTS) ATTACHMENT TO EACH OTHER HAVE A MINIMUM OF (3) 10-16 TECH SCREWS PROVIDING A CAPACITY OF 2,595 LBS IN SHEAR (S.F.=3)


USE 2" X 8", 15 ga. STRAP (G-90) AS PER PLAN SEE DETAIL

WOOD CURB (BY OTHERS)

(2) #12-14 x 1" Lg (HHH#3) HILTI KLIK-FLEX SELF DRILLING STEEL SCREW W/ WASHERS (OR EQUIVALENT)

USE 2" X 8", 15 ga. (G-90) STRAP AS PER PLAN

(4) #12 x2" Lg WOOD SCREWS W/ WASHERS



CAULK AROUND PERIMETER OF BASE PAN

BASE PAN (.045" MIN THICK.)

WOOD CURB (BY OTHERS)

**STRAP DETAIL**

<b>S-4</b>	Job No: 15-18	JOB NAME: CUBE UNIT	 <b>ROBERT E. SAMARA P.E., P.A.</b> email: samara@ppsenginc.com Consulting Engineers Structural PE # 19649
	Date: 09-11-2015	TITLE: CLIP AND ATTACHMENT LOCATION PLAN (FOR WOOD CURB)	
	Chkd By: R. Samara		
	Drawn By: A. Barnett		
			4675 PONCE de LEON BLVD, #303 CORAL GABLES, FL 33146 Ph: 305-662-1916 Fax: 305-662-2491

**WIND ANALYSIS AND ANCHOR DESIGN FOR UTC CARRIER "Cube Style Base Pan Units", FOR RESIDENTIAL OCCUPANCY, WITH BASE PAN SIZE NO GREATER THAN 35 INCHES SQUARE (CATEGORY II) (FOR BUILDINGS OF 60 FEET OR LESS IN HEIGHT AND MAXIMUM WIND VELOCITY OF 180 MPH) (MAXIMUM HEIGHT OF UNIT 47.44 INCHES)**

**References:**

**ASCE 7-10 " Minimum Design Loads for Buildings and Other Structures"  
Florida Building Code 2014, 5th Edition**

**Design Criteria:**


**Paragraph 6.5.15 "Design Wind Loads on Open Buildings and Other Structures"**

**Note that 2 sides of these units are open and the other 2 sides are partially open)**

**Wind Analysis (For heights up to 60 feet and 180 mph velocity) Risk Factor = 1.0**

Wind design velocity	$V_{ww} := 180$	
Wind speed conversion	$V_{asd} := V \cdot \sqrt{0.6}$	$V_{asd} = 139.427$
Structure Category	II	(Table 1.5-1 "(ASCE)
Height above ground	$H_{ww} := 60$	ft
Height of structure	$h := 48$	in
Dimension of unit	$D := 35$	in
Area resisting wind forces	$A_f := \frac{h \cdot D}{144}$	$A_f = 11.667 \text{ ft}^2$
Gust effect factor	$GC_f := 3.1$	1620.6 FBC-14)
Velocity Exposure Coefficient	$K_z := 1.13$	(Table 29.3-1) Exposure C) (ASCE)
Topographic multipliers	$K_1 := 0$	Section 26.6-1) (ASCE)
	$K_2 := 0$	Section 26.6-1) (ASCE)
	$K_3 := 0$	Section 26.6-1) (ASCE)
Topographic Factor	$K_{zt} := (1 + K_1 \cdot K_2 \cdot K_3)$	$K_{zt} = 1$ (Section 26.8-1) (ASCE)
Wind Directionality Factor	$K_d := 0.9$	Section 26.6-1) (ASCE)
Velocity pressure	$q_z := \left( 0.00256 K_z \cdot K_{zt} \cdot K_d \cdot V_{asd}^2 \right)$	$q_z = 50.612 \text{ psf}$ (29.3-1) (ASCE)
Design Wind Force	$F_{ww} := q_z \cdot GC_f$	$F = 156.899 \text{ psf}$ (Eq. 29.5-2) (ASCE)
	$\frac{F}{144} = 1.09$	ksi

**Note that vertical Unit Panels are attached to Base Pans with at least (3) S-MD 10-16 Screws , each side, with a shear capacity of 865 pounds each, with a safety factor of (3) and a total capacity of 2595 pounds**

<b>S-5</b>	Job No: 15-18	JOB NAME:	<b>CUBE BASE UNIT</b>	 <b>ROBERT E. SAMARA P.E., P.A.</b> email: samara@ppsenginc.com Consulting Engineers Structural PE # 19649
	Date: 09-11-2015			
	Chkd By: R. Samara	<b>WIND ANALYSIS AND CALCULATIONS</b>		
	Drawn By: A. Barnett	4675 PONCE de LEON BLVD. #303 CORAL GABLES, FL 33146 Ph: 305-662-1916 Fax: 305-662-2491		

Attachment of the "35" X 35" Base Cube" units are designed to resist 180 mph wind forces for use up to heights of 60 feet with Uplift Clips as described below.

Design Criteria:	Width (feet)	Height (feet)	Area (square feet)	Moment arm (feet)
	$w := \frac{D}{12}$	$h_1 := \frac{h}{12}$	$A_{f1} := w \cdot h_1$	$a_1 := \frac{D}{2 \cdot 12}$
	$w = 2.917$	$h_1 = 4$	$A_{f1} = 11.667$	$a_1 = 1.458$

Maximum wind moments and overturning reaction forces on each unit

$$M_1 := A_{f1} \cdot \frac{h_1}{2} \cdot F \quad M_1 = 3.661 \times 10^3 \text{ (ft lbs)} \quad F_1 := \frac{M_1}{a_1} \quad F_1 = 2.51 \times 10^3 \text{ (pounds)}$$

Anchor design of base pan to support pad

### ANCHOR DESIGN OF BASE PAN TO CONCRETE SUPPORT PAD WITH 2" X 4" TIE-DOWN CLIPS

Screw Design (Vertical Attachment to Base Pan (Shear capacity of (2) 12-14 screws per Clip)

$$V_s := 6 \cdot 526 \quad V_s = 3.156 \times 10^3 \text{ lbs.} \quad \text{Number/Screws/Clip (2)}$$


Tensile capacity of (3) 1/4" Anchor devices for Uplift Clips

$$F_{kb} := 505 \cdot 6 \quad F_{kb} = 3.03 \times 10^3 \text{ lbs} \quad \text{Number/Anchors/Clip (2)}$$

Try (3) 2" x 4" Tie-down Clips on each side with minimum capacity of 914 lbs.

$$T_s := 3 \cdot 914 \quad T_s = 2.742 \times 10^3 \quad \text{Number/Clips/Unit (12)}$$

Use 2" X 4", 15 guage, "Steel Tie-Down Clips, by BMP International, Inc." Attach (3) Clips at each side as close to each corner as possible. Use (2) No. 12-14 x 1" (HWH) Hilti Self Drilling steel screws, or equal, at each Uplift Clip with a shear capacity of 526 lbs per screw (working stress). For Clip to foundation attachment use 1/4" x 2 1/4" hex head stainless steel "Buildex" Tapcon Steel Screws (SHW4-214) and 5/16" stainless steel washer with an uplift capacity of 505 lbs. per anchor, or 1/4" x 2 1/4" hex head blue coated "Buildex" Tapcon Screws (HW4-214) and 5/16" stainless steel washer, or use (2) 1/4" x 3" long "Powers Wedge Bolt" heavy duty anchors and 5/16" stainless steel washer, with uplift capacity of 900 lbs per anchor in 2500 psi concrete. (See attached drawing )

<b>S-6</b>	Job No:	15-18	JOB NAME: <b>CUBE BASE UNIT</b>	 <b>ROBERT E. SAMARA P.E., P.A.</b> email: samara@ppsenginc.com Consulting Engineers Structural PE # 19649
	Date:	09-11-2015		
	Chk'd By:	R. Samara	TITLE: <b>WIND ANALYSIS AND CALCULATIONS</b>	
	Drawn By:	A. Barnett		
			4675 PONCE de LEON BLVD. #303 CORAL GABLES, FL 33146 Ph: 305-662-1916 Fax: 305-662-2491	

**Maximum wind moments and overturning reaction forces on each unit**

$$M_1 := A_{fl} \cdot \frac{h_1}{2} \cdot F \quad M_1 = 3.661 \times 10^3 \text{ (ft lbs)} \quad F_1 := \frac{M_1}{a_1} \quad F_1 = 2.51 \times 10^3 \text{ (pounds)}$$

**Screw Design (Vertical Attachment to Base Pan (Shear capacity of (2) 12-14 Tech screws per strap)**

$$V_s := 6 \cdot 526 \quad V_s = 3.156 \times 10^3 \text{ lbs.} \quad \text{Number/Screws/strap (2)}$$

**Shear capacity of (12) #12 x 2" long stainless Wood Screws for Uplift Clips (256 lbs. per Screw)**

$$F_{kb} := 256 \cdot 12 \quad F_{kb} = 3.072 \times 10^3 \text{ lbs} \quad \text{Number of wood Screws/ strap (4)}$$

**Try (2) Tie-Down Straps on each side with minimum capacity of 914 lbs. (Controlled by wood screws)**

$$T_s := 3 \cdot 914 \quad T_s = 2.742 \times 10^3 \quad \text{Number/straps/Unit (12)}$$

Use 2" X 8", 15 guage, "Steel Tie-Down Straps, by BMP International, Inc." Attach (3) Straps at each side as close to each corner as possible. Use (2) No. 12-14 x 1" (HWH) Hilti Self Drilling steel Screws at each Uplift Strap to Base Pan, with a shear capacity of 526 lbs per screw (working stress) . Use (4) No. 12 x 2" stainless steel Wood Screws at each Uplift Strap to Wood Base Curb with a shear capacity of 256 lbs per screw

**ANCHOR DESIGN OF BASE PAN TO ROOF STAND WITH 2" X 4" TIE-DOWN CLIPS, WITH ADDED UPLIFT**

$$G_{Cf} := 1.5 \quad (1620.6) \quad \text{(FBC-14)}$$

$$F_r := G_{Cf} \cdot q_z \quad F_r = 75.919 \quad F_{up} := F_r \cdot A_{fl} \quad F_{up} = 885.718$$

$$F_{1adj} := F_1 + \frac{F_{up}}{8} \quad F_{1adj} = 2.621 \times 10^3$$

**Screw Design (Vertical Attachment to Base Pan) Shear capacity of (6) Tech Screws for uplift)**

$$V_s := 6 \cdot 526 \quad V_s = 3.156 \times 10^3 \text{ lbs.} \quad \text{Number/Screws per Clip (2)}$$


**Shear capacity of (6) 1/4" stainless #12-14 Tech Screws for Uplift Straps to Metal Roof Stand**

$$F_{kb} := 526 \cdot 6 \quad F_{kb} = 3.156 \times 10^3 \text{ lbs} \quad \text{Number/Anchors/Clip (2)}$$

**Try (3) Uplift Clips on each side with minimum capacity of 914 lbs. (Controlled by Clip capacity)**

$$T_s := 3 \cdot 914 \quad T_s = 2.742 \times 10^3 \quad \text{Number/Clips/Unit (12)}$$

Use 2" X 4", 15 guage, "Steel Tie-Down Clips, by BMP International, Inc." Attach (3) Clips at each side. Use (2) No. 12-14 x 1" (HWH) Hilti Self Drilling steel Screws at each Uplift Clip to Base Pan, with a shear capacity of 526 lbs per screw (working stress), or equal . Use (2) 1/4" x 1 1/2" stainless steel thru bolts, with washers for Uplift Clips to Metal Roof Stand connection.

<b>S-7</b>	Job No: 15-18	JOB NAME:	<b>CUBE BASE UNITS</b>	 <b>ROBERT E. SAMARA P.E., P.A.</b> email: samara@ppsenginc.com Consulting Engineers Structural PE # 19649
	Date: 09-11-2015			
	Chk'd By: R. Samara			
	Drawn By: A. Barnett	TITLE:		
			4675 PONCE de LEON BLVD. #303 CORAL GABLES, FL 33146 Ph: 305-662-1916 Fax: 305-662-2491	

UTC

35" X35" BASE CUBE HP UNITS

DESIGN FOR BUILDINGS 60 FEET OR LESS IN HEIGHT

References:


Florida State Building Code 2014 5th Edition  
 ASCE 7-10 "Minimum Design Loads for Buildings and Other Structures"

Design criteria:

Individual exterior and wind exposed panels are evaluated for their capacity to resist wind forces for 180 mph velocity and 60 feet in height. Stress analysis is based on drawings, dimensions and section properties provided by UTC for their Cube Units.

Part No.	Height (in)	Eff Width (in)	Moment (in kips)	Steel pan yield stress : $f_y$	$f_y = 30 \cdot 1.33$	Sect. Mod. $I_x$ $I_y$ in <sup>3</sup>	Resisting Moment Capacity (in kips)
SERVICE PANEL	$s_1 := 41.3$	$w_1 := 14.63$	$M_1 := \frac{0.125 \cdot w_1 \cdot F \cdot s_1^2}{1000}$	$f_y := 30 \cdot 1.33$	$f_y = 39.9$	$S_{I_x} := 0.007788$ $S_{I_y} := 0.9377$	$M_{r1} := f_y \cdot (S_{I_x} + S_{I_y})$ $M_{r1} = 37.725$
CNTR BOX COVE R	$s_2 := 18.02$	$w_2 := 11.47$	$M_2 := \frac{0.125 \cdot w_2 \cdot F \cdot s_2^2}{1000}$			$S_{2x} := 0.003443$ $S_{2y} := 0.6209$	$M_{r2} := f_y \cdot (S_{2x} + S_{2y})$ $M_{r2} = 24.911$
LOUVER PANEL 1	$s_3 := 40.78$	$w_3 := 20.27$	$M_3 := \frac{0.125 w_3 \cdot F \cdot s_3^2}{1000}$			$S_{x3} := 0.0020911$ $S_{3y} := 0.69759$	$M_{r3} := f_y \cdot (S_{x3} + S_{3y})$ $M_{r3} = 27.917$
LOUVER PANEL 2	$s_4 := 40.78$	$w_4 := 17.14$	$M_4 := \frac{0.125 \cdot w_4 \cdot F \cdot s_4^2}{1000}$			$S_{x4} := 0.021$ $S_{4y} := 0.30364$	$M_{r4} := f_y \cdot (S_{x4} + S_{4y})$ $M_{r4} = 12.953$
SHEET TUBE	$s_5 := 40.78$	$w_5 := 17.14$	$M_5 := \frac{1.976 \times 10^3 \cdot 12}{1000}$			$S_{x5} := 6.7116$	$M_{r5} := f_y \cdot S_{x5}$ $M_{r5} = 267.793$

**NOTE: ALL OF THE WIND RESISTING EXTERIOR PANELS, INDIVIDUALLY MEET OR EXCEED THEIR CAPACITY TO RESIST THE DESIGN WIND LOADS AS STATED IN THE CALCULATIONS AS REQUIRED BY THE FLORIDA STATE BUILDING CODE 2014. DUE TO THE INDETERMINENT NATURE OF THESE UNITS, DISTORTION AND DEFLECTION CANNOT BE ACCURATELY EVALUATED, BUT WITH DIAPHRAGM ACTION OF EXTERNAL COMPONENTS AND INTERNAL STIFFENERS, THE BASE UNIT HAS THE CAPACITY TO WITHSTAND THESE FORCES WITH INDIVIDUAL EXTERNAL PARTS BEING CONTAINED. YEARLY INSPECTIONS OR DURING EQUIPMENT MAINTENANCE. ALL TECH SCREWS, CABINET COMPONENTS, CLIPS AND ANCHOR BOLTS ARE TO BE VERIFIED BY THE A/C CONTRACTOR. ALL DAMAGED CABINET COMPONENTS, LOOSE, CORRODED, BROKEN TECH SCREWS OR ANCHOR BOLTS SHALL BE REPLACED TO ENSURE STRUCTURAL INTEGRITY FOR HURRICANE WIND FORCES**



**ROBERT E. SAMARA P.E., P.A.**  
 email: samara@ppsenginc.com  
 Consulting Engineers  
 Structural PE # 19649

4675 PONCE DE LEON BLVD, # 303  
 CORAL GABLES, FL 33146  
 Ph: 305-662-1916 Fax: 305-662-2491

JOB NAME:	CUBE BASE UNITS
TITLE:	PARTS ANALYSIS AND CALCULATIONS

Job No:	15-18
Date:	09-11-2015
Chk'd By:	R. Samara
Drawn By:	A. Barnett

**S-8**