

## Installation Instructions

# Evaporator Coil



A-Coil and  
Multi-Position A-Coil  
Pages 4 - 6



Slab Coil  
Page 7



Horizontal A-Coil  
Top Connections  
Page 7



Horizontal A-Coil  
Side Connections  
Page 7



## GENERAL

ADP evaporator coils are designed for use with condensing units or heat pump units. These instructions are intended as a general guide and do not supersede local codes in any way. Consult with local authorities having jurisdiction before installation. **Read this installation manual and all "Warning" statements prior to installing the evaporator coil.**

Check coil for shipping damage and verify the contents of the box containing the evaporator coil. If you should find damage, immediately contact the last carrier. Verify the efficiency requirements are appropriate with the matched condensing or heat pump units such as capacity, SEER, EER, and/or HSPF. Check outdoor unit manufacturer for proper line sizing. **Coils are shipped with a 10 psi dry air holding charge. Puncture rubber plug on suction line to release charge before removing plugs.** The absence of pressure does not verify a leak. Check the coil for leaks before installing or returning it to your wholesaler.

Position the coil on the outlet of the furnace using sheet metal screws. Drain pans are made of a polymer that can withstand temperatures up to 450°F. **Maintain a 3" clearance on oil or drum type heat exchangers and 1½" on sectionalized heat exchangers.** Coil should be level, or pitched slightly toward the drain connection. **Airflow face velocity above 350 ft/min is not recommended for downflow or counterflow applications due to potential water blow-off.** Refer to Specification Guide for limitations.

\*\* Note: Large tonnage A-Coils and Slab Coils (greater than 5 tons) are not AHRI certified and do not have Microban protection.



Product improvement is a continuous process at Advanced Distributor Products. Therefore, product specifications are subject to change without notice and without obligation on our part. Please contact your ADP representative or distributor to verify details.  
© by Advanced Distributor Products. All rights reserved.

# REFRIGERANT METERING

Coils are suited for R-22 and R-410A refrigerants and can be used with or without a TXV. Replacement TXV part numbers are listed below; see kit instructions for change out or installation. ADP recommends placing a wet rag around the suction line at the cabinet during brazing to prevent overheating and damaging the sensing bulb. For optimum performance, reattach and insulate the bulb at a 10 to 2 o'clock position outside of the cabinet to the main suction line no more than one foot from the suction line connection. When changing a system from AC to heat pump or heat pump to AC, check the current TXV specifications to determine if a TXV replacement is required. **If the evaporator coil contains a non-bleed TXV and is used with a condensing unit containing a reciprocating compressor, a hard start mechanism will be required on the outdoor unit.**

Large Tonnage A-Coils of 7.5 Ton (R-410A) cooling capacity include an adjustable TXV that can be used to fine tune superheat. Turn adjustment clockwise to increase superheat 4°F per turn and counterclockwise to decrease superheat 4°F per turn. To return to factory setting, turn adjustment stem counterclockwise until the spring is completely unloaded (reaches stop or starts to “ratchet”). Then, turn it back 6 “total turns”.

R-22 TXV Part Numbers		R-410A TXV Part Numbers	
18-36 MBTUH Bleed A/C	65540600	18-36 MBTUH Non-Bleed A/C	65026401
42-60 MBTUH Bleed A/C	65540700	42-60 MBTUH Non-Bleed A/C	65026400
18-36 MBTUH Non-Bleed A/C	99167501	18-36 MBTUH Non-Bleed A/C-HP	65616601
42-60 MBTUH Non-Bleed A/C	99167502	42-60 MBTUH Non-Bleed A/C-HP	65616602
18-36 MBTUH Non-Bleed A/C-HP	65616201		
42-60 MBTUH Non-Bleed A/C-HP	65616202		

## ! IMPORTANT !

When changing the expansion valve, the TXV MUST match the refrigerant type and capacity of the condensing unit. Failure to do so will result in poor performance and possible compressor damage. All coils must be matched properly as listed in the AHRI directory.

Cased coils with a piston metering device are shipped with a cap and hex nut over the threaded fitting. Remove the cap and nut slowly, allowing charge to escape, and secure the liquid line stub (attached to cabinet) to the distributor assembly with hex nut. Discard cap.

For optimum performance, the piston should be sized to match the recommendation from the outdoor unit manufacturer. If the outdoor unit manufacturer does not recommend a piston size, refer to the piston size chart on page 3.

When changing ADP pistons, refer to Figure 1 and use the following procedure:

1. Loosen hex nut located on liquid line and separate from distributor assembly.
2. Remove the existing piston from inside the distributor assembly.
3. Insert the desired ADP piston into the distributor assembly.
4. Inspect Teflon O-Ring and replace if damaged. Ensure Teflon O-Ring is in place.
5. Re-install hex nut to body and torque to 10 ft-lbs.




Figure 1

Piston Size				
Ton	R-22		R-410A	
	Piston Size	Part #	Piston Size	Part #
1	41	100000035	41	100000035
1.5	53	100000036	49	100000049
2	59	100000037	53	100000036
2.5	67	100000039	59	100000037
3	73	100000041	67	100000039
3.5	80	100000044	73	100000041
4	84	100000045	76	100000042
5	93	100000047	93	100000047

## CONDENSATE DRAIN

Coils are equipped with multiple drain connections. Determine the drain connections to be used and note the difference between the primary (green) and secondary (red) openings. Drain plugs are provided for all openings, remove and discard the appropriate plugs with ½" drive ratchet and verify that remaining plugs are tight. (2.5 ft-lbs) Attach drain line to pan with ¾" male pipe thread PVC fittings. Hand tight is adequate – **do not over tighten & do not reduce drain line size!**

Route drain(s) line so they will not be exposed to freezing temperatures and do not interfere with accessibility to the coil, air handling system or filter. The drain should be pitched downward 1" per 10' with a 2" trap as close to the coil as possible. If line makes a second trap, or has an extended run before termination, a vent tee should be installed after the trap closest to the pan. See Figure 2.

If the coil is located in or above a living space where damage may result from condensate overflow, a separate ¾" drain must be provided from the secondary drain connection. Run this drain to a place in compliance with local installation codes where it will be noticed when unit is operational. Condensate flowing from the secondary drain indicates a plugged primary drain. Prime the trap with water. Test line for leaks. Test water flow with unit in operation. **An auxiliary drain pan should also be installed under the unit as specified by most local building codes.**




Figure 2

### ! WARNING !

This product may contain fiberglass wool insulation. Glass wool fibers are known to the State of California to cause cancer. Disturbing insulation during installation, maintenance, or repair may expose you to glass wool fibers and may cause respiratory, skin or eye irritation. For further information on risks associated with fiberglass wool, consult Material Safety Data Sheet available from OEM.

### IMPORTANT

The Clean Air Act of 1990 bans the intentional venting of refrigerant (CFC's and HFC's). Approved methods of reclaiming must be followed. Fines and/or incarceration may be levied for non-compliance.

# A-COIL

A-Coils are designed for upflow/downflow applications. Vertical drain pans have drain connections on the right and left front side of the evaporator coil. **Airflow face velocity above 350 ft/min is not recommended for downflow applications due to potential water blow-off.** Refer to Specification Guide for limitations. In downflow applications, aluminum foil tape must be applied to seal the top edge of the insulation to the cabinet. This tape will prevent the possibility of the insulation delaminating and blocking airflow.

## MULTI-POSITION A-COIL


Multi-Position A-Coils come factory installed with a vertical and horizontal drain pan, which can be configured for upflow, downflow, horizontal blow-through or horizontal pull-through installations. In the center opening of vertical drain pan, a metal Inlet Air Restrictor is factory installed and is required for horizontal applications. It may be removed for vertical applications. Airflow face velocity above 350 ft/min is not recommended for downflow or counterflow applications due to potential water blow-off. Refer to Specification Guide for limitations. For horizontal configurations, install splashguard (included) onto the coil outlet, and extend suction line insulation into the coil cabinet by 2" to prevent moisture from dripping onto the insulation (the rubber grommet may need to be removed). Splashguard installation is not required for vertical configurations. Bottom flange of guard should rest on pan and sides screwed to the duct flanges. See page 5, Figures 4 & 5 for splashguard instructions.

In downflow and pull-through configurations aluminum foil tape must be applied to seal the top edge of the insulation to the cabinet. This tape will prevent the possibility of the insulation delaminating and blocking airflow. In horizontal pull-through configurations, a minimum 12" transition is required in front of the coil as shown in the figure below. This is required to ensure proper airflow distribution and to reduce pressure drop. Coils that are 20" or less in height and are installed in a cabinet with a height of 25-1/2" or greater do not require a transition; all other coil models require this transition. Coil should be level, or pitched slightly toward the drain connection. It is recommended to add silicone caulk between drain pans to prevent water carryover. **Note: Multi-Position A-Coils are also field convertible from left-to-right or right-to-left; see page 6 for instructions on field conversion for horizontal airflow.**

### Pre system startup checklist for Multi-Position A-Coils – Refer to Figure 3

- Is splash guard installed? (**Figure 3 Configurations A and B**)
- Airflow adjusted to rated CFM?
- Is 12" transition installed as shown below? (non-standard horizontal applications)
- Factory installed Inlet Air Restrictor present in the center opening of the drain pan (horizontal applications)?
- Factory installed internal water diverter in place? Refer to Multi-Position A-Coil Field Conversion on page 6.
- Unit slightly tilted toward drain connection used?
- Drain line connected and trapped per these instructions?

Figure 3



# MULTI-POSITION A-COIL SPLASHGUARD




Figure 4 – Splashguard without front slope




Figure 5 – Splashguard with front slope

# MULTI-POSITION A-COIL FIELD CONVERSION

## Field Conversion Instructions from Left-to-Right or Right-to-Left Airflow

**Note:** This applies only to models available in multi-position; see Specification Guide for details; typical horizontal left-to-right conversion is shown.

### FOR EACH STEP, REFER TO FIGURE 6 BELOW:

1. Remove front panels and top tie bar. Pull the coil assembly from the housing.
2. Remove top tie bar and pull the coil assembly from the housing.
3. Remove the horizontal drain pan, and re-install it to the opposite side of the coil. (Note: horizontal drain pan must have drain plugs tightly closed in the rear of the unit).
4. Remove the top plate.
5. Remove the water diverter, and re-install it to the opposite slab. (Note: If your water diverter is attached by screws, remove screws, and bend tab straight or cut tab off).
6. Replace the top plate, and apply sealant to seal any air gaps.
7. Before re-inserting the coil assembly, cut the front flange on the housing and fold it back to allow access to the horizontal drain connections (Note: Copy the factory cut-out on the opposite side of the housing).
8. Slide the coil assembly back into the housing. (Note: If unit is equipped with a sheet metal housing adapter, it must be moved to the opposite side of the housing).
9. Re-install the top tie bar.
10. Re-install the piping panel to the housing.
11. Cut a hole in the access panel to allow access to the horizontal drain connections, and re-install the access panel to the housing. (Note: Access panel may need to be notched to allow access to suction header).
12. Seal old condensate drain connection cutout holes in the front panel to prevent air leakage.




Figure 6

Diagram shows typical conversion from left hand to right hand

# HORIZONTAL A-COIL & SLAB COIL

Horizontal A-Coils and Slab Coils are designed for horizontal applications only. Proper performance for Horizontal A-Coils with top connections requires that the air flow out through the tip of coil (Figure 7). Horizontal A-Coils with side connections are bidirectional. Slab Coils are bidirectional and require a transitional duct to complete installation. Horizontal A-Coils 17.5" and taller include furnace plate adaptors to facilitate proper fit with furnaces of different widths. For Horizontal A-Coils with side connections, the suction line section inside the cabinet should be insulated with Armaflex® insulation (Figure 8).



Figure 7 – Horizontal A-Coil w/ top connections




Figure 8 – Horizontal A-Coil w/ side connections



# REFRIGERANT CHARGING INSTRUCTIONS

---

When charging in cooling mode, the outdoor temperature should be 60°F or higher. To allow the pressures to stabilize, operate the system a minimum of 10 minutes between adjustments.

**TXV** – Use the subcooling recommended by the outdoor unit instructions, or use the range of 6°F to 15°F subcooling. If equipped, adjust the TXV to 6°F to 10°F superheat.

**Fixed Orifice** – Use the superheat recommended by the outdoor unit instructions, or use the superheat table below.

Outdoor Air Temp. (°F)	60	65	70	75	80	85	90	95	100	105	110	115
Nominal Superheat (°F)	31	28	25	22	20	16	13	10	8	6	5	5
Minimum Superheat (°F)	28	25	22	20	16	13	10	6	6	4	4	4

For heat pumps initially charged in the cooling mode, final adjustment in heating mode is acceptable if necessary. When charging heat pumps in the heating mode, refer to the outdoor unit charging instructions.



2175 West Park Place Boulevard  
Stone Mountain, GA 30087  
[www.adpnow.com](http://www.adpnow.com)