

Carrier, Bryant, Payne & Midea Model ICP Model	38MAGB09R--1 DLC5RAH09AAJ	38MAGB12R--1 DLC5RAH12AAJ	38MAGB09R--3 DLC5RAH09AAK	38MAGB12R--3 DLC5RAH12AAK	38MAGB18R--3 DLC5RAH18AAK	38MAGB24R--3 DLC5RAH24AAK	38MAGB30R--3 DLC5RAH30AAK	38MAGB36R--3 DLC5RAH36AAK	38MAGB36A--3 DLC1RAH36AAK
Dimensions	21.8	21.8	21.8	21.8	27.6	31.9	31.9	31.9	31.9
Height	32.1	32.1	32.1	32.1	33.7	37.2	37.2	37.2	40.6
Width	13.1	13.1	13.1	13.1	14.2	16.1	16.1	16.1	17.9
Depth	82.9	82.9	91.5	91.5	118.2	145.5	139.8	147.3	136.6
Weight-Net									

Carrier, Bryant, Payne & Midea Model ICP Model	38MGRQC18--3 DLC1RAH18AAK	38MGRQD24C--3 DLC1RAH24CAK	38MGRQ30D--3 DLC1RAH30DAK
Dimensions	27.6	41.2	41.2
Height	37.3	31.9	31.9
Width	14.8	17.9	17.9
Depth	105.8	149.9	156.5
Weight-Net			

Carrier, Bryant, Payne & Midea Model ICP Model	38MPPRAQ09AA3 DLC1RAH09AAK	38MPPRAQ12AA3 DLC1RAH12AAK
Dimensions	27.6	27.6
Height	33.3	33.3
Width	14.3	14.3
Depth	107.6	108.5
Weight-Net		

Carrier, Bryant, Payne (cooling only) Carrier, Bryant, Payne (heat pump)	38MHRQ09A--1 38MHRQ09A--1	38MHRQ12A--1 38MHRQ12A--1	38MHRQ09A--3 38MHRQ09A--3	38MHRQ12A--3 38MHRQ12A--3	38MHRQ18A--3 38MHRQ18A--3	38MHRQ24A--3 38MHRQ24A--3
Dimensions	21.9	21.9	21.9	21.9	21.8	27.6
Height	30.3	30.3	30.3	30.3	31.5	33.3
Width	11.8	11.8	11.8	11.8	13.1	14.3
Depth	57.3	57.8	54.7	53.8	70.1	88.6
Net Weight						
Cooling Only					94.6	105.2
Net Weight	61.5	65	57.1	60.6		
Heat Pump						

Carrier Model Cooling Only	38MHRBC12AA1
Carrier, Bryant & Payne Model Heat Pump	38MHRBQ12AA1
Bryant, Payne, ICP Model Cooling Only	DLCERAA12AAJ
Bryant, Payne, ICP Model Heat Pump	DLCERAH12AAJ
Unit Height (in)	21.85
Unit Width (in)	30.31
Unit Depth (in)	11.81
Net Weight (lbs) Cooling Only	57.8
Net Weight (lbs) Heat Pump	69.0

Carrier, Bryant, Payne, ICP, Midea (cooling) Carrier, Bryant, Payne, ICP, Midea (H.P.)	38MHRBQ12AA1 DLCERAA12AAJ	38MHRBQ09AA-3 DLCERAA12AAK	38MHRQ12A-3 DLCERAA12AAK	38MHRQ18A-3 DLCERAA18AAK	38MHRQ24AA3 DLCERAA24AAK
ICP (cooling only)					
ICP (heat pump)	DLCERAH12AAJ	DLCERAH09AAK	DLCERAH12AAK	DLCERAH18AAK	DLCERAH24AAK
Dimensions	21.85	21.85	21.85	21.81	27.64
Height	30.31	30.31	30.31	31.5	33.27
Width	11.81	11.81	11.81	13.11	14.29
Depth	57.8	53.8	70.1		88.6
Net Weight					
Cooling Only				79.6	114.2
Net Weight	69	63	65.5		
Heat Pump					

Toshiba, Carrier	Outdoor Models	RAV-SP180AT2-UL	RAV-SP240AT2-UL
Height	in	21.7	35
Width	in	30.7	35.4
Depth	in	11.4	12.6
Weight/Net	lbs	98	144

Carrier Model Number Bryant Model Number ICP Model Number	38GRQ09--3 538FEO09R8GA DLCAB09K1A	38GRQ12--3 538FEO12R8GA DLCAB12K1A	38GRQ18--3 538FEO18R8GA DLCAB18K1A	38GRQ24--3 538FEO24R8GA DLCAB24K1A	38GRQ30--3 538FEO30R8GA DLCAB30K1A
Dimensions	23.5	23.5	31.1	31.1	31.1
Height	35.4	35.4	38.6	38.6	38.6
Width	14.9	14.9	16.8	16.8	17.3
Depth	99.2	97	141.1	144.7	145.5
Net Weight					

Toshiba, Carrier Outdoor Models	RAS-09EACV-UL RAS-09EAV-UL RAS-09EAV2-UL	RAS-12EACV-UL RAS-12EAV-UL RAS-12EAV2-UL	RAS-15EACV-UL RAS-15EAV-UL RAS-15EAV2-UL	RAS-17EACV-UL RAS-17EAV-UL RAS-17EAV2-UL	RAS-22EACV-UL RAS-22EAV-UL RAS-22EAV2-UL
Height	21.7	21.7	21.7	21.7	21.7
Width	30.7	30.7	30.7	30.7	30.7
Depth	11.4	11.4	11.4	11.4	11.4
Weight/Net	82	88	91	91	93

THE UNIT MODELS LISTED BELOW WERE ANALYZED TO MEET THE REQUIREMENTS OF THE FLORIDA BUILDING CODE (2017) AND THE ASCE 7-16 WIND ANALYSIS CODE. THE UNITS AND CONNECTIONS WERE ANALYZED FOR 186 MPH WIND SPEED AT 60 FEET ABOVE GROUND FOR CATEGORY III AND IV STRUCTURES.

Robert E. Samara 9/17/18




ROBERT E. SAMARA P.E., P.A.
 email: samara@ppsenginc.com
 Consulting Engineers
 Structural PE # 19649

4675 PONCE de LEON BLVD, #303
 CORAL GABLES, FL 33146
 Ph: 305-662-1916 Fax: 305-662-2491






**CARRIER, BRYANT AND ICP
 DUCTLESS SPLIT SYSTEMS 09K TO 36K
 2017 CODE REVISION MODELS LIST - GROUP ONE**

Job No: 18-1
 Date: 04-12-2018
 Rev Date:
 Chk'd By: R. Samara
 Drawn By: A. Barnet


JOB NAME:
 TITLE:




NOTE: ALL OF THE WIND RESISTING EXTERIOR PANELS, INDIVIDUALLY MEET OR EXCEED THEIR CAPACITY TO RESIST THE DESIGN WIND LOADS AS STATED IN THE CALCULATIONS AS REQUIRED BY THE FLORIDA STATE BUILDING CODE 2017 6th EDITION, DUE TO THE INDETERMINANT NATURE OF THESE UNITS, DISTORTION AND DEFLECTION CANNOT BE ACCURATELY EVALUATED, BUT WITH DIAPHRAGM ACTION OF EXTERNAL COMPONENTS AND INTERNAL STIFFENERS, THE BASE UNIT HAS THE CAPACITY TO WITHSTAND THESE FORCES WITH INDIVIDUAL EXTERNAL PARTS BEING CONTAINED. YEARLY INSPECTIONS OR DURING EQUIPMENT MAINTENANCE, ALL TECH SCREWS, CABINET COMPONENTS, AND ANCHOR BOLTS ARE TO BE VERIFIED BY THE A/C CONTRACTOR. ALL DAMAGED CABINET COMPONENTS, LOOSE, CORRODED, BROKEN TECH SCREWS OR ANCHOR BOLTS SHALL BE REPLACED TO ENSURE STRUCTURAL INTEGRITY FOR HURRICANE WIND FORCES




ASSEMBLY DRAWING




ROOF STAND (BY OTHERS) SEE CALCULATIONS FOR FORCES
 USE 2X4, 15 GA STEEL TIE DOWN CLIPS BY BMP INTERNATIONAL INC WITH (2) 1/4" DIA X 1-1/2" LG SS THRU BOLTS TO STAND W/ WASHERS AND 2 (12-14) TEK SCREWS TO BASE PAN (TYP AS SHOWN)




CHASSIS BASE PAN
 USE 2X4, 15 GA STEEL TIE DOWN CLIPS BY BMP INTERNATIONAL INC WITH (2) 1/4" DIA X 1-1/2" LG SS THRU BOLTS TO STAND W/ WASHERS AND 2 (12-14) TEK SCREWS TO BASE PAN (TYP AS SHOWN)




CAULK AROUND PERIMETER OF BASE PAN
 PT WOOD CURB (BY OTHERS) SEE CALCULATIONS FOR FORCES
 USE 2X4, 15 GA STEEL TIE DOWN CLIPS BY BMP INTERNATIONAL INC WITH (1) 1/4" X 4" LG LAG BOLTS W/ WASHERS AND 2 (12-14) TEK SCREWS TO BASE PAN (TYP AS SHOWN)



CHASSIS BASE PAN
 USE 2X4, 15 GA STEEL TIE DOWN CLIPS BY BMP INTERNATIONAL INC WITH (1) 1/4" X 4" LG LAG BOLTS W/ WASHERS AND 2 (12-14) TEK SCREWS TO BASE PAN (TYP AS SHOWN)



USE 2X4, 15 GA STEEL TIE DOWN CLIPS BY BMP INTERNATIONAL INC WITH (1) 1/4" Ø x 3" LG POWERS WEDGE BOLT HEAVY DUTY CONCRETE ANCHORS AND 2 (12-14) TEK SCREWS TO BASE PAN (TYP AS SHOWN)



FOR CONCRETE FOUNDATION ATTACHMENT USE:
 USE 2X4, 15 GA STEEL TIE DOWN CLIPS BY BMP INTERNATIONAL INC WITH (1) 1/4" Ø x 3" LG POWERS WEDGE BOLT HEAVY DUTY CONCRETE ANCHORS AND 2 (12-14) TEK SCREWS TO BASE PAN (TYP AS SHOWN)

Robert Samara 4/17/18

ROBERT E. SAMARA P.E., P.A.
 email: samara@ppsenginc.com
 Consulting Engineers
 Structural PE # 19649

4675 PONCE de LEON BLVD, #303
 CORAL GABLES, FL 33146
 Ph: 305-662-1916 Fax: 305-662-2491

JOB NAME: **CARRIER, BRYANT AND ICP DUCTLESS SPLIT SYSTEMS 09K TO 36K- GROUP ONE**

TITLE: **ASSEMBLY DRAWING & CONCRETE ATTACHMENT LOCATION PLAN**

Job No: 18-1
 Date: 04-12-2018
 Rev Date:
 Chkd By: R. Samara
 Drawn By: A. Barnett

02

S-2

References: ASCE 7-16 "Minimum Design Loads for Buildings and Other Structures" Florida Building Code 2017 6th Edition

Design Criteria:

FBC 2017, Section 1620, "High Velocity Hurricane Zone, Wind Loads" (Risk Category III & IV) Section 1620.6 "Roof Equipment and Structures"

Wind Analysis (For heights up to 60 feet & 186 MPH wind) with an Importance Factor of 1.0 (Note that vertical uplift is neglected due to the open grille on top and enclosed base curb)

Wind design velocity $V_{ASD} = 186$

Wind speed conversion $V_{ASD} = V \sqrt{0.6}$ $V_{ASD} = 144.075$

Risk Category III & IV (Table 1604.5) (Table 1.5-1 (ASCE 7-16))

Importance Factor $I = 1.0$ FBC-17 (Table 1.5-2 (ASCE 7-16))

Height above ground $H_{AG} = 60$ ft

Height of structure $h = 35.0$ in

Width of unit $D = 12.6$ in

Length of unit $L_{UN} = 35.4$ in

Area resisting wind forces $A_f = \frac{h \cdot L}{144}$ $A_f = 8.604$ ft²

Gust effect factor/Force coeff. $G_{CF} = 1.9$ (FBC-17)

Velocity Exposure Coefficient $K_z = 1.31$ (Table 26-10-1)(Exposure "D") (ASCE 7-16)

Topographic multipliers $K_1 = 0$ (Figure 26-8-1 (ASCE 7-16))

$K_2 = 0$ (Figure 26-8-1 (ASCE 7-16))

$K_3 = 0$ (Figure 26-8-1 (ASCE 7-16))

Topographic Factor $K_{zt} = (1 + K_1 \cdot K_2 \cdot K_3)$ $K_{zt} = 1$ (Equation 26-8-1) (ASCE 7-16)

Wind Directionality Factor $K_d = 1.0$ (Table 26-6-1 (ASCE 7-16))

Velocity pressure $q_z = 0.00256 K_z K_{zt} K_d V_{ASD}^2$ $q_z = 69.613$ psf (Eq. 26-10-1 (ASCE 7-16))

Design Wind Force $F_{DC} = q_z G_{CF}$ $F = 132.264$ psf (Eq. 29-5-1 (ASCE 7-16))

UTC-DUCTLESS-30K_UNITS DESIGN BUILDINGS FOR 186 MPH WIND VELOCITY AND 60 FEET OR LESS IN HEIGHT

References: Florida State Building Code 2017 6th Edition ASCE 7-10 "Minimum Design Loads for Buildings and Other Structures"

Design criteria: Maximum Load Conditions for Individual Interior Panels are evaluated for their capacity to resist wind forces for 186 mph velocity at 60 feet height. Stress analysis is based on drawings, dimensions and section properties provided by UTC for their DUCTLESS-30K Units.

Wind force: $F_{DC} = 919$ psi Steel pan yield stress: $f_t = 33,133$ $f_c = 43,89$ ksi

Part No. Height (in) Eff Width (in) Moment (in kips)

SIDE PANEL $s_1 = 30.56$ $w_1 = 27.49$ $M_1 = \frac{0.125 \cdot w_1 \cdot F \cdot s_1^2}{1000}$ $M_1 = 2.949$ Sect. Mod. in³ Resisting Moment Capacity (in kips)

END PANEL $s_2 = 13.87$ $w_2 = 30.35$ $M_2 = \frac{0.125 \cdot s_2 \cdot F \cdot w_1^2}{1000}$ $M_2 = 1.204$ $S_{yx} = 0.490418$ $M_2 = f_t (S_{yx})$ $M_2 = 21.524$

NOTE: Uplift Force on Top Panel 0.712 psi

TOP PANEL $s_3 = 36.41$ $w_3 = 14.47$ $M_3 = \frac{0.125 \cdot w_3 \cdot F \cdot s_3^2}{1000}$ $M_3 = 1.707$ $S_{yx} = 0.06022$ $S_{yx} = 0.010454$ $M_3 = f_t S_{yx} + f_c S_{yx}$ $M_3 = 3.102$

(UPLIFT)

ANCHOR DESIGN OF BASE PAN TO CONCRETE SUPPORT PAD WITH (6) ATTACHED HOLD DOWN BRACKETS

NOTE: The distance from center of clip vertical leg to vertical leg of Unit is 13.0 inches $D_{CL} = 13.0$ in

Design Criteria:

Width (feet) Height (feet) Area (square feet) Moment arm (feet)

$w = \frac{L}{12}$ $h_1 = \frac{h}{12}$ $A_{H1} = w \cdot h_1$ $a_1 = \frac{D}{12}$

$w = 2.95$ $h_1 = 2.917$ $A_{H1} = 8.604$ $a_1 = 1.083$

Maximum wind moments and overturning reaction forces on each unit

$M_1 = A_{H1} \cdot \frac{h_1}{2} \cdot F$ $M_1 = 1.66 \times 10^3$ (ft lbs) $F_1 = \frac{M_1}{a_1}$ $F_1 = 1.532 \times 10^3$ (pounds per long side)

Screw Design (Vert. Attachment to Base Pan (Shear capacity of (6) 12-14 TEK Screws (Long Side) (540 lbs./screw) for 15 ga clips and basepan base metal (16 ga))

$V_s = 6.540$ $V_s = 3.24 \times 10^3$ lbs. $F_{kb} = 3.066 \times 10^3$ lbs

Tensile capacity of (3) 1/4 x 3" long Anchor devices for Uplift Clips per long side.

Try (3) 2" x 4" The-Down Clips (15 ga) on each side with minimum capacity of 1070 lbs

$T_s = 3.1070$ $T_s = 3.21 \times 10^3$ Number/Clips/Unit (6)

Use 2" x 4" 15 gauge, "Steel The-Down Clips, by BMP International, Inc. Use (3) Clips evenly spaced along each long side. Use (2) No. 12-14 x 1" (HWH) Hill Self Drilling steel screws, or equal at each Uplift Clip with a shear capacity of 540 lbs per screw (working stress). Use (1) 1/4" x 3" Power Wedge bolt Heavy duty Anchors and 5/16" dia Stainless Steel washers per clip with uplift cap. of 1022 lbs. per anchor in 3000 PSI concrete (See attached drawings).

ANCHOR DESIGN OF BASE PAN TO WOOD ROOF CURB WITH (6) ATTACHED HOLD DOWN BRACKETS

Design Criteria: Width (feet) Height (feet) Area (square feet) Moment arm (feet)

$w = \frac{L}{12}$ $h_1 = \frac{h}{12}$ $A_{H1} = w \cdot h_1$ $a_1 = \frac{D}{12}$

$w = 2.95$ $h_1 = 2.917$ $A_{H1} = 8.604$ $a_1 = 1.083$

Screw Design (Vert. Attachment to Base Pan (Shear capacity of (2) 12-14 TEK Screws (Long Side) (540 lbs./screw) for 15 ga clips and 16 ga basepan

$V_s = 6.540$ $V_s = 3.24 \times 10^3$ lbs. $F_{kb} = 3.066 \times 10^3$ lbs

Tensile capacity of (6) 1/4" Stainless Thru Bolts for "Steel The-Down Clips" to Metal Roof Stand at long sides

Try (3) 1/4 inch diameter by 4 inch long Wood Lag Bolts with minimum capacity of 260 lbs. per inch.

$T_s = 3.910$ $T_s = 2.73 \times 10^3$ Number/Lag Bolts/Bracket (1) Number/Brackets/Unit (6)

Use (3) 1/4 inch Wood Lag Bolts by 4 inches long 3/12 inches effective), each side with minimum capacity of 910 lbs. each. (See attached drawings.)

ANCHOR DESIGN OF BASE PAN TO METAL ROOF STAND WITH (8) ATTACHED HOLD DOWN BRACKETS, WITH ADDED WIND UPLIFT AT ROOF PANEL

Design Criteria: Width (feet) Height (feet) Area (square feet) Moment arm (feet)

$w = \frac{L}{12}$ $h_1 = \frac{h}{12}$ $A_{H1} = w \cdot h_1$ $a_1 = \frac{D}{12}$

$w = 2.95$ $h_1 = 2.917$ $A_{H1} = 8.604$ $a_1 = 1.083$

Maximum wind moments and overturning reaction forces on each unit

$M_1 = A_{H1} \cdot \frac{h_1}{2} \cdot F$ $M_1 = 1.66 \times 10^3$ (ft lbs) $F_{kb} = \frac{M_1}{a_1}$ $F_{kb} = 1.532 \times 10^3$ (pounds per long side)

$F_{adj} = F_{up} + \frac{F_{up} \cdot A_{H1}}{6}$ $F_{adj} = 3.164 \times 10^3$

Screw Design (Vert. Attachment to Base Pan (Shear capacity of (6) 12-14 TEK Screws (Long Side) and (4) 12-14 Tek Screws short sides), 540 lbs./screw

$V_s = 6.540$ $V_s = 3.24 \times 10^3$ lbs. $F_{kb} = 3.066 \times 10^3$ lbs

$V_s = 16.540$ $V_s = 8.64 \times 10^3$ lbs. $F_{adj} = 3.164 \times 10^3$ Number/Screws/Clip (2) Number/Screws/Clip (2)

Tensile capacity of (6) 1/4" Stainless Thru Bolts for "Steel The-Down Clips" to Metal Roof Stand at long sides

Try (3) Uplift Clips on each long side and (1) on each short side with minimum capacity of 1070 lbs.

$T_s = 8.1070$ $T_s = 8.56 \times 10^3$ Number/Clips/Unit (6)

Use 2" x 4" 15 gauge, "Steel The-Down Clips, by BMP International, Inc. Use (3) Clips evenly spaced along each long side and (1) on each short side. Use (2) 1/4" x 1 1/2" Stainless Steel Thru Bolts per "Steel The-Down Clip", with 5/16" dia S.S. washers to Metal Roof Stand connection and (2) #12-14 TEK Screws per clip attached to base pan (See attached drawings).

Robert Samara 4/17/18

Carrier, Bryant, Payne & Midea Model	38MBRQ48A--3	38MBRQ58A--3
ICP Model	DLCRAH48AAK	DLCRAH58AAK
Dimensions		
Height	in	52.5
Width	in	37.5
Depth	in	16.3
Weight - Net	lbs	217.4
		225.1

Carrier, Bryant, Payne & Midea Model	38MGRQ36D--3	38MGRQ48E--3
ICP Model		DLCMRAH48EAK
Dimensions		
Height	in	52.5
Width	in	41.2
Depth	in	17.6
Weight-Net	lbs.	221.6
		223.8

Carrier Model Number	38GJQF36---3	38GJQG42---3	38GJQK48---3	38GJQL56---3
Bryant Model Number	538KEQ036RGA	538KEQ042RGA	538KEQ048RGA	538KEQ056RGA
ICP Model Number	DLCBHR36K1A	DLCBHR30K1A	DLCBHR48K1A	DLCBHR56K1A
Dimensions				
Height	in	43.4	43.4	53
Width	in	42.8	42.8	35.4
Depth	in	17.3	17.3	13.4
Net Weight	lbs	198.4	198.4	255.7

Toshiba, Carrier	Outdoor Models	RAV-SP300AT2-UL	RAV-SP360AT2-UL	RAV-SP420AT2-UL
Height	in	52.8	52.8	52.8
Width	in	35.4	35.4	35.4
Depth	in	12.6	12.6	12.6
Weight/Net	lbs	211.5	211.5	211.5

Carrier & Bryant Model	38VMA036HDS301	38VMA048HDS301	38VMA060HDS301
Unit Height (in)	52.3	52.3	52.3
Unit Width (in)	35.5	35.5	35.5
Unit Depth (in)	15.8	15.8	15.8
Net Weight (lbs)	220.0	220.0	220.0

Robert Samara 4/17/18



ROBERT E. SAMARA P.E., P.A.
 email: samara@ppsenginc.com
 Consulting Engineers
 Structural PE # 19649

4675 PONCE de LEON BLVD, #303
 CORAL GABLES, FL 33146
 Ph: 305-662-1916 Fax: 305-662-2491


**CARRIER, BRYANT AND ICP
 DUCTLESS SPLIT SYSTEMS 36K TO 60K**

TITLE: **2017 CODE REVISION MODELS LIST - GROUP TWO**


Job No:	18-1
Date:	04-12-2018
Rev Date:	
Chk'd By:	R. Samara
Drawn By:	A. Barnett

THE UNIT MODELS LISTED BELOW WERE ANALYZED TO MEET THE REQUIREMENTS OF THE FLORIDA BUILDING CODE (2017) AND THE ASCE 7-16 WIND ANALYSIS CODE. THE UNITS AND CONNECTIONS WERE ANALYZED FOR 186 MPH WIND SPEED AT 60 FEET ABOVE GROUND FOR CATEGORY III AND IV STRUCTURES.


NOTE: ALL OF THE WIND RESISTING EXTERIOR PANELS, INDIVIDUALLY MEET OR EXCEED THEIR CAPACITY TO RESIST THE DESIGN WIND LOADS AS STATED IN THE CALCULATIONS AS REQUIRED BY THE FLORIDA STATE BUILDING CODE 2017 (6th Edition). DUE TO THE INDETERMINANT NATURE OF THESE UNITS, DISTORTION AND DEFLECTION CANNOT BE ACCURATELY EVALUATED, BUT WITH DIAPHRAGM ACTION OF EXTERNAL COMPONENTS AND INTERNAL STIFFENERS, THE BASE UNIT HAS THE CAPACITY TO WITHSTAND THESE FORCES WITH INDIVIDUAL EXTERNAL PARTS BEING CONTAINED. YEARLY INSPECTIONS OR DURING EQUIPMENT MAINTENANCE, ALL TECH SCREWS, CABINET COMPONENTS, AND ANCHOR BOLTS ARE TO BE VERIFIED BY THE A/C CONTRACTOR. ALL DAMAGED CABINET COMPONENTS, LOOSE, CORRODED, BROKEN TECH SCREWS OR ANCHOR BOLTS SHALL BE REPLACED TO ENSURE STRUCTURAL INTEGRITY FOR HURRICANE WIND FORCES




ASSEMBLY DRAWING



ROOF STAND ATTACHMENT DETAIL



WOOD CURB ATTACHMENT DETAIL



FOUNDATION ATTACHMENT DETAIL

Robert Samara 9/17/18

Job No:	18-1
Date:	04-12-2018
Rev Date:	
Chk'd By:	R. Samara
Drawn By:	A. Barnet

JOB NAME: CARRIER, BRYANT AND ICP
 DUCTLESS SPLIT SYSTEMS 36K TO 60K - GROUP TWO
 TITLE: ASSEMBLY DRAWING & CONCRETE ATTACHMENT LOCATION PLAN

ROBERT E. SAMARA P.E., P.A.
 email: samara@ppsenginc.com
 Consulting Engineers
 Structural PE # 19649

4675 PONCE de LEON BLVD, #303
 CORAL GABLES, FL 33146
 Ph: 305-662-1916 Fax: 305-662-2491

2017 WIND ANALYSIS AND ANCHOR DESIGN FOR UTC (DUCTLESS 60K UNITS)

References:
 ASCE 7-16 "Minimum Design Loads for Buildings and Other Structures"
 Florida Building Code 2017, 6th Edition

Design Criteria:
 FBC 2017, Section 1620. "High Velocity Hurricane Zone, Wind Loads" (Risk Category III & IV)
 Section 1620.6 "Roof Top Equipment and Structures"

Wind Analysis (For heights up to 60 feet & 186 MPH wind) Importance Factor=1.0
 (Note that vertical uplift is neglected due to the open grille on top and enclosed base curb)

Wind design velocity $V_{wd} = 186$

Wind speed conversion $V_{asd} = V \sqrt{0.6} \quad V_{asd} = 144.075$

Risk Category III & IV (Table 1.5-1 (ASCE 7-16))

Importance Factor I = 1.0 (FBC-17 (TABLE 1.5-2, ASCE 7-16))

Height above ground $H_g = 60$ ft

Height of structure $h = 52.8$ in

Depth of unit $D = 13.4$ in

Length of unit $L = 35.4$ in

Area resisting wind forces $A_r = 144$ ft²

Gust effect factor/Force Coeff. $GCF = 1.9$ (1620.6 (FBC-17))

Velocity Exposure Coefficient $K_z = 1.31$ (Table 26-10-1 (Exposure "D") (ASCE 7-16))

Topographic multipliers $K_1 = 0$ (Section 26.8-1 (ASCE 7-16))

$K_2 = 0$ (Section 26.8-1 (ASCE 7-16))

$K_3 = 0$ (Section 26.8-1 (ASCE 7-16))

Topographic Factor $K_{zt} = (1 + K_1 K_2 K_3)$ (Equation 26.8-1) (ASCE 7-16)

Wind Directionality Factor $K_d = 1$ (Table 26-6-1 (ASCE 7-16))

Velocity pressure $q_z = 0.00256 K_z K_{zt} K_d V_{asd}^2$ $q_z = 69.613$ psf (Eq. 26-10-1 (ASCE 7-16))

Design Wind Force $F_{wi} = q_z GCF$ $F = 132.264$ psf (Eq. 29.5-2 (ASCE 7-16))

$F = 0.919$ psi

UTC-DUCTLESS-60K_UNITS DESIGN BUILDINGS FOR 186 MPH WIND VELOCITY AND 60 FEET OR LESS IN HEIGHT

References:

Florida State Building Code 2017 6th Edition
 ASCE 7-16 "Minimum Design Loads for Buildings and Other Structures"

Design criteria:

Maximum Load Conditions for Individual interior panels are evaluated for their capacity to resist wind forces for 186 mph velocity at 60 feet height. Stress analysis is based on drawings, dimensions and section properties provided by UTC for their DUCTLESS-60K Units.

Wind force: $F_w = 919$ psi Steel pan yield stress: $f_y = 33,133$ $f_t = 43,89$ ksi

Part No. Height (in) Eff Width (in) Moment (in kips) Sect. Mod. in³ Resisting Moment Capacity (in kips)

FRONT PANEL $s_1 = 51.52$ $w_1 = 26.58$ $M_1 = \frac{0.125 w_1 F_w s_1^2}{1000}$ $M_1 = 8.105$ $S_{1x} = 0.05722$ $S_{1y} = 0.37590$ $M_{r1} = f_t (S_{1x}) + f_y (S_{1y})$ $M_{r1} = 19.01$

END PANEL $s_2 = 52.39$ $w_2 = 12.42$ $M_2 = \frac{0.125 s_2 F_w w_1^2}{1000}$ $M_2 = 4.252$ $S_{2y} = 0.399681$ $M_{r2} = f_t (S_{2y})$ $M_{r2} = 17.542$

TOP COVER (UPLIFT) $s_3 = 18.46$ $w_3 = 14.47$ $M_3 = \frac{0.125 w_3 F_w s_3^2}{1000}$ $M_3 = 0.566$ $S_{3x} = 0.026922$ $S_{3y} = 0.010454$ $M_{r3} = f_t S_{3x} + f_y S_{3y}$ $M_{r3} = 1.64$

ANCHOR DESIGN OF BASE PAN TO CONCRETE SUPPORT PAD WITH (8) ATTACHED HOLD DOWN BRACKETS

NOTE: The distance from compression face of Unit to center of anchor location is 14.3 inches

$D_{ca} = 14.3$ in

Design Criteria: Width (feet) Height (feet) Area (square feet) Moment arm (feet)

$w = \frac{L}{12}$ $h_1 = \frac{h}{12}$ $A_{\eta} = w h_1$ $a_1 = \frac{D}{12}$
 $w = 2.95$ $h_1 = 4.4$ $A_{\eta} = 12.98$ $a_1 = 1.192$

Maximum wind moments and overturning reaction forces on each unit

$M_1 = A_{\eta} \frac{h_1}{2} F$ $M_1 = 3.777 \times 10^3$ (ft-lbs)
 $F_1 = \frac{M_1}{a_1}$ $F_1 = 3.169 \times 10^3$ (pounds per long side)

Screw Design (Vert. Attachment to Base Pan (Shear capacity of (12) 12-14 TEK Screws (Long Side) (540 lbs. / screw) for 12 ga clips and basepan base metal (16 ga))

$V_s = 12.540$ $V_s = 6.48 \times 10^3$ lbs. Number/Screws/Clip (3)

Tensile capacity of (3) 3/8" x 4" long Anchor devises for Uplift Clips per long side.

$F_{Rb} = 2205.4$ $F_{Rb} = 8.82 \times 10^3$ lbs Number/Anchors/Clip (1)

Try (4) 2" x 4" Tie-down Clips (12 ga) on each side with minimum capacity of 3300 lbs

$T_s = 4.3300$ $T_s = 1.32 \times 10^4$ Number/Clips/Unit (8)

Use 2" x 4", 12 gauge, "Steel Tie-Down Clips, by BMP International, Inc. Use (4) Clips evenly spaced along each long side. Use (3) No. 12-14 x 1" (HWH) Hilti Self Drilling steel screws, or equal at each Uplift Clip with a shear capacity of 540 lbs per screw (Working stress). Use (1) 3/8" x 4" Power Wedge bolt Heavy duty Anchors and 7/16" dia Stainless Steel washers per clip with uplift cap. of 2205 lbs. per anchor in 3000 PSI concrete (See attached drawings).

UPLIFT WIND FORCES FOR "DUCTLESS-60K UNITS" WITH ATTACHMENT TO METAL ROOF STAND

Gust effect factor $S_{GC} = 1.50$ (29.5-3)

Design Wind Force $F_{up} = q_z GCF$ $F_{up} = 104.419$ psf $F_{up} = 0.725$ psi

ANCHOR DESIGN OF BASE PAN TO METAL ROOF STAND WITH (10) ATTACHED HOLD DOWN BRACKETS, WITH ADDED WIND UPLIFT AT ROOF PANEL

Design Criteria: Width (feet) Height (feet) Area (square feet) Moment arm (feet)

$w = \frac{L}{12}$ $h_1 = \frac{h}{12}$ $A_{\eta} = w h_1$ $a_1 = \frac{D}{12}$
 $w = 2.95$ $h_1 = 4.4$ $A_{\eta} = 12.98$ $a_1 = 1.192$

Maximum wind moments and overturning reaction forces on each unit

$M_{1x} = A_{\eta} \frac{h_1}{2} F$ $M_1 = 3.777 \times 10^3$ (ft-lbs)
 $F_{1x} = \frac{M_1}{a_1}$ $F_1 = 3.169 \times 10^3$ (pounds per long side)

$F_{adj} = F A_{\eta}$ $F_{up} = 1.717 \times 10^3$ $F_{adj} = F_1 + \frac{F_{up} A_{\eta}}{8}$ $F_{adj} = 5.955 \times 10^3$ $a_1 = 1.192$

Screw Design (Vert. Attachment to Base Pan (Shear capacity of (12) 12-14 TEK Screws (Long Side) and (6) 12-14 Tek Screws short sides), 540 lbs. / screw

$V_s = 12.540$ $V_s = 6.48 \times 10^3$ lbs. Number/Screws/Clip (3)

$V_s = 18.540$ $V_s = 9.72 \times 10^3$ lbs. Number/Screws/Clip (3)

Tensile capacity of overturning and uplift (12) 1/4" Stainless Thru Bolts for "Steel Tie-Down Clips" to Metal Roof Stand (8) at ea. long side and (2) each short side.

$F_{Rb} = 980.20$ $F_{Rb} = 1.96 \times 10^4$ lbs Number/Thru Bolts/Bracket (2)

Try (4) Uplift Clips on each long side and (1) on each short side with minimum capacity of 3300 lbs. (Controlled by TEK Screw shear capacity)

$T_s = 10.3300$ $T_s = 3.3 \times 10^4$ Number/Clips/Unit (10)

Use 2" x 4", 12 gauge, "Steel Tie-Down Clips, by BMP International, Inc. Use (4) Clips evenly spaced along each long side and (1) each short side. Use (2) 1/4" x 1 1/2" Stainless Steel Thru Bolts per "Steel Tie-Down Clip", with 5/16" dia S.S. washers to Metal Roof Stand connection and (3) #12-14 TEK Screws per clip attached to base pan (See attached drawings).

ANCHOR DESIGN OF BASE PAN TO WOOD ROOF CURB WITH (8) ATTACHED HOLD DOWN BRACKETS

Design Criteria: Width (feet) Height (feet) Area (square feet) Moment arm (feet)

$w = \frac{L}{12}$ $h_1 = \frac{h}{12}$ $A_{\eta} = w h_1$ $a_1 = \frac{D}{12}$
 $w = 2.95$ $h_1 = 4.4$ $A_{\eta} = 12.98$ $a_1 = 1.192$

Screw Design (Vert. Attachment to Base Pan (Shear capacity of (12) 12-14 TEK Screws (Long Side) (540 lbs. / screw) for 12 ga clips and basepan

$V_s = 12.540$ $V_s = 6.48 \times 10^3$ lbs. Number/Screws/Clip (3)

Try (4) 3/8 inch diameter by 5 inch long Wood Lag Bolts with minimum capacity of 260 lbs. per inch.

$T_s = 4.1584$ $T_s = 6.336 \times 10^3$ Number/Lag Bolts/Bracket (1)

Use (4) 3/8 inch Wood Lag Bolts by 5 inches long (4 1/2 inches effective) (each side with minimum capacity of 1584 lbs. each. (See attached drawings)

Robert E. Samara 4/17/18

ROBERT E. SAMARA P.E., P.A.
 email: samara@ppsenginc.com
 Consulting Engineers
 Structural PE # 19649
 4675 PONCE de LEON BLVD, #303
 CORAL GABLES, FL 33146
 Ph: 305-662-1916 Fax: 305-662-2491

CARRIER, BRYANT AND ICP
DUCTLESS SPLIT SYSTEMS 36K TO 60K - GROUP TWO
WIND / PARTS ANALYSIS AND CALCULATIONS

JOB NAME: **18-1**
 Date: **04-12-2018**
 Rev Date:
 Chkd By: **R. Samara**
 Drawn By: **A. Barnett**

06

S-3