



VRF Tech Bulletin – 001-2018

Today's date: 6.08.2018

**Carrier Enterprise
Technical Services**

Scenario – Carrier Toshiba VRF with one or more IDU's with no local remote controller and a centralized control utilizing the TCS Relay.

In the event you have the above application an additional setup procedure must be done in the TCS-net relay or the system will error out during commissioning. Currently this setup procedure is not in any of the documentation that is provided with the equipment.

When setting up the TCS-net relay set the SW-3-4 DIP switch to ON and then recycle power to TCS-net Relay. Start all other equipment and controls as you normally would.



TCS-net Relay

