


Curb Mounting

Part Number BRK-CRBHOLD-01: Z-Bracket Kit (Curb)  
One Kit Contains: Qty. 4 - Z-Brackets  
Qty. 16 - 1/4" x 6" TEK Screws  
Qty. 8 - 1/4" x 1" TEK Screws  
Qty. 1 - Instructions  
One Kit Required per Unit



Z-Bracket with  
Qty. 4 - 1/4" x 6" TEK Screws  
4 Places

BRYANT Chassis 1 & 2:


Models: 580J/558J, 559K and 548J - size 04 (min) through 07(max)  
582J/559J, 581J/551J and 549J - size 04(min) through 06 (max)

Each package unit air conditioner listed above conforms to the Florida Building Code 6<sup>th</sup> Edition (2017) requirements for installation including High Velocity Hurricane Zone (HVHZ), Risk Category III/IV (V = 186 MPH), exposure category "D", and installation height up to and including 65 feet above grade. Worst case is -07 (chassis 2) 74-3/8" x 46-3/4" x 41-3/8" tall.


ALLOWABLE DESIGN PRESSURES FOR THE UNIT ITSELF:

Design Lateral Pressure = 197.18 lb/ft<sup>2</sup>  
Design Uplift Pressure = 95.41 lb/ft<sup>2</sup>

Unit itself will withstand wind loads imposed by 197.18 PSF lateral and 95.41 PSF uplift design pressures provided the 16 gage galvanized base rails are properly fastened to a suitable slab, curb, curb adapter, or other suitable mounting arrangement and all factory supplied assembly fasteners are in place.




Z-Bracket Installed on Roof Curb prior to installation of seal strip & RTU



Z-Bracket Wind Load Fastening to RTU to Roof Curb

Optional Mounting



Part Number BRIDC-KGR: Tie-Down Bracket Kit (Concrete or Stand)  
One Kit Contains: Qty. 2 - Tie-Down Brackets  
Qty. 6 - 1/4" x 3/4" Self-Drilling Screws with Washers  
Qty. 2 - 3/8" x 2-1/4" Ultra-Wedge Anchors (Concrete)  
Qty. 1 - Instructions  
Qty. 2 - 3/8" x 1" Bolts, Washers and Nuts (Stand)  
Three Kits Required per Unit



John Buerosse, P.E., P.A.  
Structural and Mechanical Engineering  
750 E. Sample Road - Bldg. 3 - #220  
Pompano Beach, FL 33064  
Tel: 954-633-4692 Fax: 954-784-004

Job No.: Bryant Rooftop Units  
Title: Model List and Details

Job No. Chase 1 & 2  
Date:  
Created by: J. Buerosse

Rational Analysis: Worst case is -07 (Chassis 2) 74-3/8" x 46-3/4" x 41-3/8" tall

Design Pressures complying to FBC Building 1620.6 (HVHZ):

V = 186 mph (Risk Cat. III/IV), For Exp. Cat. "D" and Z = 65 ft, Kz = 1.33, Kzt = 1.0, Kd = 0.90  
qz = .00256KzKzKdV2 = 106.01 lb/ft2  
Using 1620.6,  
Lateral Wind Pressure = WL = qz(3.1) = 328.64 lb/ft2  
Uplift Wind Pressure = UL = qz(1.5) = 159.02 lb/ft2  
Factoring in the required Load Combination factor (0.6):

Design Lateral Pressure = WL(0.6) = 197.18 lb/ft2

Design Uplift Pressure = UL(0.6) = 95.41 lb/ft2

Since positive pressure acts toward the surface being considered and negative pressure acts away, only the uplift pressure will remove a panel from the machine. The design lateral pressure which is considered to act toward the windward surface is recognized to be a combination of the pressures acting on the windward and leeward surfaces. Wall pressure coefficients from ASCE7-10, Chapter 27, Figure 27.4-1 may be used to distribute the Design Lateral Pressure into positive and negative components acting on the windward and leeward surfaces, respectively.

L/B = 46.75/74.375 = 0.63 for wind on long (74-3/8") side  
L/B = 74.375/46.75 = 1.59 for wind on short (46-3/4") side

Worst case positive pressure coefficient is 0.8 for windward wall which has a corresponding negative pressure coefficient of 0.5 on the leeward wall. The worst case negative pressure coefficient is 0.7 for the sidewall (side parallel to wind). Since the windward and leeward wall pressures act in the same direction, the distributed pressures are computed as follows:

Lateral Positive Design Pressure = 197.18 (0.8) / (0.8 + 0.5) = 121.34 lb/ft2 (Worst Case Positive)

Lateral Negative Design Pressure = 197.18 (0.5) / (0.8 + 0.5) = 75.84 lb/ft2

Sidewall Negative Design Pressure = 197.18 (0.7) / (0.8 + 0.5) = 106.17 lb/ft2 (Worst Case Negative)

22 ga. panels and columns are fastened together and to 16 ga. base rails using #10 serrated washer head self piercing screws having 0.425" head diameter, 0.19" nominal diameter, and 0.14 minor diameter. These screws are expected to exhibit the following properties based upon ICC-ES Report ESR-2196:

Pullout Strength in 22 ga. = 306 lbs (ultimate)

Pullover strength of 22 ga. = 828 lbs (ultimate)

Shear Strength in 22 ga. = 684 lbs (ultimate)

Pullout Strength in 16 ga. = 450 lbs (ultimate – based upon 18 ga.)  
Shear Strength in 16 ga. = 927 lbs (ultimate – based upon 18 ga.)

For Top Panel (48TCS00235):

73.6" x 45" draw formed panel anchored at edges and through top to center panel and control box. Worst case portion is over air handler section since condenser section has a large hole in the top causing internal and external pressure to be equal. For portion tributary to air handling section:

A = 45(38.6)/12(12) = 12.06 ft2

Load = 12.06 (95.41) = 1150.9 lbs

For outside edge (7 screws, all in shear), screw load = 1150.9/2(7) = 82.2 lbs

Safety Factor = 684/82.2 = 8.3 OK

For inside edge (8 screws, 4 in tension), screw load = 1150.9/2(8) = 71.9 lbs

Safety Factor = 306/71.9 = 4.3 OK Sheet 5

For Inside Panel (50HJS40465):

44.84" x 37.53" draw formed panel anchored at edges with 5 screws through face at top and bottom and 5 screws each vertical edge through flange perpendicular to face (10 screws in tension, 10 screws in shear).

A = 44.84(37.53)/ 12(12) = 11.69 sqft

Load = 11.69(106.17) = 1240.7 lbs

Screw Load = 1240.7/20 = 62.04 lbs

Safety Factor = 306/62.04 = 4.9 OK

For Access Door ( 48TM500284):

33.5" x 36.5" draw formed panel anchored with 2 screws through face each vertical side, 3 screws through face at bottom edge and top edge fits inside top panel (trapped).

A = 33.5(36.5)/12(12) = 8.49 sqft

Load = 8.49(106.17) = 901.5 lbs

Screw Load = 901.5/2(5) = 90.15 lbs

Safety Factor = 306/90.15 = 3.4

OK for Components and Cladding

For Access Panel ( 48TM500345):

12.13" x 37.3" draw formed panel anchored with 1 screw through face each vertical side, 1 screw through face at bottom edge and top edge fits inside top panel (trapped).

A = 12.13(37.3)/12(12) = 3.14 sqft

Load = 3.14(106.17) = 333.6 lbs

Screw Load = 333.6/2(3) = 55.60 lbs

Safety Factor = 306/55.60 = 5.5 OK for Components and Cladding

Remaining panels are trivial cases of the above due to greater fastener quantity or having openings that limit negative pressure effects.

For connection of upper frame and panels to base rails:

12 screws each long side fasten frame columns and panels to the long base rails. 5 screws fasten inside panel to short base rail at air handler end. Opposite end is louvered and has a large opening in the top and mesh over cooling coils. Screws fasten 22 ga. panels and columns to 16 ga. base rails.

Lateral Wind Area = AL = 73.6(37.53)/12(12) = 19.18 sqft

Lateral Design Load = 19.18(197.18) = 3782 lbs

Overturning Moment = 3782(37.53)/2 = 70975 in-lb

Uplift Wind Area = AU = 73.6(45)/12(12) = 23.0 sqft

Uplift Design Load = 23.0(95.41) = 2194 lbs

Uplift Moment = 2194(45)/2 = 49375 in-lb

Screw Load = (70975 + 49375)/12(45) = 222.9 lbs (shear)

Safety Factor = 927/222.9 = 4.2 OK

Unit itself will withstand wind loads imposed by 197.18 psf lateral and 95.41 psf uplift design pressures provided the 16 gage galvanized base rails are properly fastened to a suitable slab, stand, curb, curb adapter, or other suitable mounting arrangement and all factory supplied assembly fasteners are in place.

For connection of unit base rails to properly designed curb, metal stand, or structural concrete (by others):

Lateral Wind Area = AL = 74.375(41.375)/12(12) = 21.37 sqft

Lateral Design Load = 21.37(197.18) = 4214 lbs

Overturning Moment = 4214(41.375)/2 = 87,172 in-lb

Uplift Wind Area = AU = 74.375(46.75)/12(12) = 24.15 sqft

Uplift Design Load = 24.15(95.41) – 0.6(607) = 1940 lbs

Uplift Moment = 1940(46.75)/2 = 45,348 in-lb

For connection of 16 ga. (min) straps, clips, or brackets spaced 48" min apart to unit base rails on long sides using 1/4" (#14) self-drilling screws:

These screws are expected to exhibit the following properties based upon ICC – ES Report ESR - 1976

Pullout Strength in 16 ga. = 573 lbs (ultimate)

Shear Strength in 16 ga. = 1389 lbs (ultimate)

Using (3) screws per strap, clip, or bracket, with (3) straps, clips, or brackets each long side:

Screw Load = (87,172 + 45,348)/3(3)(46.75) = 315.0 lbs (shear) at base rail outer surface

Safety Factor = 1389/315.0 = 4.4 OK for Components and Cladding

For Z-Brackets similar to Micromet design but modified to eliminate hidden structural fasteners anchored to 18 ga. (min) curb (by others):

Shear Strength in 18 ga. = 1218 lbs (ultimate)

Screw Load = (87172 + 45348)/3(3)(42.69) = 344.9 lbs (shear) at curb inside surface

Safety Factor = 1218/344.9 = 3.5 OK for Components and Cladding

For quantity (3) brackets 3.25" wide x 2" x 2-1/2", 16 ga. (min), spaced 24.0" (min) on-center into base rails, Using (3) screws per bracket, (3) brackets each long side:

Anchor Load = (87172 + 45348)/3(47.5) = 930.0 lbs (tension)

Anchor Load = 4214/6 = 702.3 lbs (shear) at 3/4" beyond baserail outer surface

For 3/8" SAE Gr. 5 bolts with nuts and washers to steel (by others):

Safety Factor = 3720/930.0 = 4.0 (tension)

Safety Factor = 1937/702.3 = 2.8 (shear)

For 3/8" Powers Wedge-Bolt + anchors with 2-1/8" (min) embedment into 2000 psi (min) concrete (by others), 4" (min) thick, 2-3/4" (min) edge distance, and 2-1/2" (min) spacing:

Safety Factor = 3000/930.0 = 3.2 (tension)

Safety Factor = 3100/702.3 = 4.4 (shear)

Job No.: Bryant Rooftop Units		Job No. Chase 1 &2	
Title Model List and Details		Date:	
		Created by:	J. Buerosse
		S2	




John Buerosse, P.E., P.A.  
Structural and Mechanical Engineering

750 E. Sample Road – Bldg. 3 - #220  
Pompano Beach, FL 33064  
Tel: 954-633-4692 Fax: 954-784-004

APR 05 2019



## Optional Mounting



QTY. 3 - 1/4" SDSM  
SCREWS AND WASHERS  
PER BRACKET, (6) BRACKETS

QTY. 1 - 3/8" SAE GR5 BOLT, NUT AND WASHER  
PER BRACKET INTO PROPERLY DESIGNED METAL  
STAND (BY OTHERS)

OR  
QTY. 1 - 3/8" POWERS WEDGE-BOLT+ ANCHOR  
PER BRACKET INTO MINIMUM 2000 PSI CONCRETE  
(BY OTHERS), AS FOLLOWS:  
2-1/8" MIN EMBED  
2-3/4" EDGE DISTANCE  
2-1/2" MIN SPACING



## BRYANT Chassis 3 & 4:

Models:

580J/558J - size 08 (min) through 14 (max), 548J - size 08 (min) through 12 (max)  
581J/551J - size 07 (min) through 12 (max), 549J - size 07 (min) through 09 (max)

Each condenser unit listed above conforms to the Florida Building Code 6th Edition (2017) requirements for installation including High Velocity Hurricane Zone (HVHZ), Risk Category III/IV (V = 186 MPH), exposure category "D", and installation height up to and including 65 feet above grade.

Worst Case is -09 (Chassis 4a) 88-1/8" x 59-1/2" x 49-3/4"

ALLOWABLE DESIGN PRESSURES FOR THE UNIT ITSELF:





Design Lateral Pressure = 197.2 psf

Design Uplift Pressure = 95.4 psf

Unit itself will withstand wind loads imposed by 197.2 psf lateral and 95.4 psf uplift design pressures, provided the 16 GA. galvanized base rails are fastened to a properly designed concrete slab, metal stand, curb, curb adapter, or other suitable mounting arrangement and all factory supplied assembly fasteners are in place.

## Curb Mounting

QTY. 4 - TEK .25-6.00  
GALVANIZED SHEETMETAL  
S.D. SCREWS AND WASHERS  
PER Z-BRACKET, (6) BRACKETS



Job No: Chassis 3 & 4  
Date: 2-11-16  
Created by: CORE

Job No: Bryant RTUs  
Title: Model List and Details

AUG 10 2018  
Pompano Beach, FL 33064  
954-633-4692

Rational Analysis: Worst case is -09 (Chassis 4a) 88-1/8" x 59-1/2" x 49-3/8"

Design Pressures complying to FBC Building 1620.6 (HVHZ):

V = 186 mph (Risk Cat. III/IV), For Exp.Cat. "D" and Z = 65 ft, Kz = 1.33, Kzt = 1.0, Kd = 0.90  
Qz = .00256KzKztKdV2 = 106.0 psf  
Lateral Wind Pressure = WL = qz(3.1) = 328.64 lb/ft2  
Uplift Wind Pressure = UL = qz(1.5) = 159.02 lb/ft2  
Factoring in the required Load Combination factor (0.6):

Design Lateral Pressure = WL(0.6) = 197.2 psf  
Design Uplift Pressure = UL(0.6) = 95.4 psf

Since positive pressure acts toward the surface being considered and negative pressure acts away, only the uplift pressure will remove a panel from the machine. The design lateral pressure which is considered to act toward the windward surface is recognized to be a combination of the pressures acting on the windward and leeward surfaces. Wall pressure coefficients from ASCE7-10, Chapter 27, Figure 27.4-1 may be used to distribute the Design Lateral Pressure into positive and negative components acting on the windward and leeward surfaces, respectively.

L/B = 59.5/88.125 = 0.68 for wind on long (88-1/8") side  
L/B = 88.125/59.5 = 1.48 for wind on short (59-1/2") side

Worst case positive pressure coefficient is 0.8 for windward wall which has a corresponding negative pressure coefficient of 0.5 on the leeward wall. The worst case negative pressure coefficient is 0.7 for the sidewall (side parallel to wind). Since the windward and leeward wall pressures act in the same direction, the distributed pressures are computed as follows:

Lateral Positive Design Pressure = 197.18 (0.8) / (0.8 + 0.5) = 121.3 psf (Worst Case Positive)  
Lateral Negative Design Pressure = 197.18 (0.5) / (0.8 + 0.5) = 75.8 psf  
Sidewall Negative Design Pressure = 197.18 (0.7) / (0.8 + 0.5) = 106.2 psf (Worst Case Negative)

22, 20, and 18 ga. panels and columns are fastened together and to 16 ga. base rails using #10 serrated washer head self tapping screws having 0.425" head diameter, 0.19" nominal diameter, and 0.14 minor diameter. These screws are expected to exhibit the following properties based upon ICC-ES Report ESR-2196:

Pullout Strength in 22 ga. = 306 lbs (ultimate) Pullout Strength in 20 ga. = 351 lbs (ultimate)  
Pullover Strength of 22 ga. = 828 lbs (ultimate) Pullover Strength of 20 ga. = 993 lbs (ultimate)  
Shear Strength in 22 ga. = 684 lbs (ultimate) Shear Strength in 20 ga. = 684 lbs (ultimate)  
Pullout Strength in 18 ga. = 450 lbs (ultimate)  
Shear Strength in 16 ga. = 927 lbs (ultimate)

For Top Panel (50HJ501228):  
87.32" x 57.68" draw formed 20 ga. panel anchored at edges and through top to 18 ga. center panel and 20 ga. control box. Worst case portion is over air handler section since condenser section has two large holes in the top causing internal and external pressure to be equal. For portion tributary to air handling section:  
A = 42.86(57.68)/12(12) = 17.17 sqft  
Load = 17.17 (95.41) = 1638.0 lbs

For outside edge (8) screws, all in shear through 20 ga. top panel into 22 ga. indoor panel and corner posts:  
Screw Load = 1638.0/2(8) = 102.4 lbs  
Safety Factor = 684/102.4 = 6.7  
OK for Components and Cladding

For inside edge (5) screws in tension through 20 ga. top panel into 18 ga. center panel and 4 screws in shear through top panel into 22 ga. center posts:  
Screw Load = 1638.0/2(9) = 91.0 lbs  
Safety Factor = 684/91.0 = 7.5  
OK for Components and Cladding

For Inside Panel (50DK500689):  
57.56" x 45.49" draw formed 22 ga. panel anchored at edges with 6 screws through top panel into face at top, 5 screws each vertical edge through flange perpendicular to face, and 6 screws at one inch above bottom edge through panel into base rail, and 4 screws between supply and return openings into stiffener (50DK502637) fastened to condensing coil.

A = 57.56(45.49)/12(12) = 18.18 ft2  
Load = 18.18(106.17) = 1930.5 lbs  
Screw Load = 1930.5/2(5+6) = 87.75 lbs  
Safety Factor = 450/87.75 = 5.1

For Access Panel (48TM500388):  
45.33" x 42.95" draw formed 22 ga. panel anchored with 2 screws through face each vertical side, 3 screws through face at bottom edge into 16 ga. base rail, and top edge fits inside top panel (trapped).

A = 45.33(42.95)/12(12) = 13.52 sqft  
Load = 13.52(106.17) = 1435.4 lbs  
Screw Load = 1435.4/2(2 + 3) = 143.54 lbs  
Safety Factor = 684/143.54 = 4.8

For Filter Panel (50DK506970):  
40.40" x 21.62" draw formed 20 ga. panel anchored with 3 screws through face at bottom edge and top edge fits inside top panel (trapped).

A = 40.40(21.62)/12(12) = 6.12 sqft  
Load = 6.12(106.17) = 649.8 lbs  
Screw Load = 649.8/2(3) = 108.32 lbs  
Safety Factor = 684/108.32 = 6.3

Remaining panels are trivial cases of the above due to greater fastener quantity or having openings that limit negative pressure effects.

For connection of upper frame and panels to base rails:  
12 screws each long side fasten frame columns and panels to the long base rails. 6 screws fasten inside panel to short base rail at air handler end. Opposite end is lowered and has a large opening in the top and mesh over cooling coils. Screws fasten 22 ga. (min) panels and columns to 16 ga. base rails.

Lateral Wind Area = AL = 87.32(45.63)/12(12) = 27.67 sqft  
Lateral Design Load = 27.67(197.18) = 5455 lbs  
Overturning Moment = 5455(45.63)/2 = 124443 in-lb  
Uplift Wind Area = AU = 87.32(57.68)/12(12) = 34.98 sqft  
Uplift Design Load = 34.98(95.41) = 3337 lbs  
Uplift Moment = 3337(57.68)/2 = 96242 in-lb

Screw Load = (124443 + 96242)/12(57.68) = 318.8 lbs (shear)  
Safety Factor = 927/318.8 = 2.9  
OK for Components and Cladding

Unit itself will withstand wind loads imposed by 197.18 psf lateral and 95.41 psf uplift design pressures provided the 16 gage galvanized base rails are properly fastened to a suitable slab, stand, curb, curb adapter, or other suitable mounting arrangement and all factory supplied assembly fasteners are in place.

For connection of unit base rails to properly designed curb, metal stand, or structural concrete (by others):  
Lateral Wind Area = AL = 88.12(49.375)/12(12) = 30.22 ft2  
Lateral Design Load = 30.22(197.18) = 5958 lbs  
Overturning Moment = 5958(49.375)/2 = 147090 in-lb  
Uplift Wind Area = AU = 88.12(59.5)/12(12) = 36.41 ft2  
Uplift Design Load = 36.41(95.41) = 0.6(845) = 2697 lbs  
Uplift Moment = 2697(59.5)/2 = 88272 in-lb

For connection of 16 ga. (min) straps, clips, or brackets spaced 32" min apart to unit base rails on long sides using 1/4" (#14) self-drilling screws:  
Pullout Strength in 16 ga. = 573 lbs (ultimate)  
Shear Strength in 16 ga. = 1389 lbs (ultimate)

Using (3) screws per strap, clip, or bracket, with (3) straps, clips, or brackets each long side (see sheet 4):  
Screw Load = (147090 + 88272)/3(4)(49.75) = 394.2 lbs (shear) at curb inside surface  
Safety Factor = 1389/439.5 = 3.2  
OK

For Z-brackets similar to Micromet design but modified to eliminate hidden structural fasteners anchored to 18 ga. (min) curb (by others):

Shear Strength in 18 ga. = 1218 lbs (ultimate)

Screw Load = (147090 + 88272)/3(4)(49.75) = 394.2 lbs (shear) at curb inside surface  
Safety Factor = 1218/394.2 = 3.1  
OK for Components and Cladding


For brackets 3.25" wide x 2" x 2-1/2", 16 ga. (min), spaced 32" (min) on-center each long side, Using (3) screws per bracket, (3) brackets each side:

Anchor Load = (147090 + 88272)/3(60.25) = 1302.2 lbs (tension)  
Anchor Load = 5958/6 = 993.0 lbs (shear) at 3/4" beyond base rail outer surface

For 3/8" SAE Gr. 5 bolts with nuts and washers to steel (by others):  
Safety Factor = 3720/1302.2 = 2.9 (tension)  
Safety Factor = 1937/993.0 = 2.0 (shear)  
OK

For 3/8" Powers Wedge-Bolt + anchors with 2-1/8" (min) embedment into 2000 psi (min) concrete (by others), 4" (min) thick, 2-3/4" (min) edge distance, and 2-1/2" (min) spacing:

Safety Factor = 3000/1302.2 = 2.3 (tension)  
Safety Factor = 3100/993.0 = 3.1 (shear)  
OK



Job No: Bryant RTUs  
Title: Model List and Details

Job No: Chassis 3 & 4  
Date: 1-08-16  
Created by: CORE

28.0 MIN  
 QTY. 3 - 1/4" SDSM  
 SCREWS AND WASHI  
 PER BRACKET, (8) BRAC

DETAIL A  
 SCALE 1 : 8

Models.  
580J/558J - size 16, 548J and 581J/551J - size 14,  
549J - size 12

Each condenser unit listed above conforms to the Florida Building Code 6th Edition (2017) requirements for installation including High Velocity Hurricane Zone (HVHZ), Risk Category III/IV (V = 186 MPH), exposure category "D", and installation height up to and including 65 feet above grade.

Worst Case is -16 (Chassis 5) 115-7/8" x 63-3/8" x 57-3/8"

## ALLOWABLE DESIGN PRESSURES FOR THE UNIT ITSELF:

Design Lateral Pressure = 197.2 psf  
Design Uplift Pressure = 95.4 psf

Unit itself will withstand wind loads imposed by 197.2 psf lateral and 95.4 psf uplift design pressures, provided the 16 GA. galvanized base rails are fastened to a properly designed concrete slab, metal stand, curb, curb adapter, or other suitable mounting arrangement and all factory supplied assembly fasteners are in place.

2-1/2" MIN SPACING

3.25

1.63

.75

Ø .39 THRU

GALVANIZED STEEL  
16 GA., 90 DEG. BRACKET

QTY. 4 - TEK .25-6.00  
GALVANIZED SHEETMETAL  
S.D. SCREWS AND WASHERS  
PER Z-BRACKET, (8) BRACKETS

**GALVANIZED STEEL, 16 GA.  
SECURE Z-BRACKET TO  
INSIDE CURB PRIOR TO  
ROOFTOP INSTALL**

ROOFTOP BASE PAN-  
SEAL STRIP (BY OTHERS)  
2X .25 X 1.00 (SUPPLIED)

-4X .25 X 6.00 (SUPPLIED)

DETAIL C  
SCALE 1:4

Job No:

Data: 2-11-16

Created by: **CORE**

Job No:

**Title:**

AUG 10 2018  
 John M. Lucarose  
 Florida P.E. 0050867-  
 750 E. Sample Road  
 Bldg. 3, Suite 220  
 Pompano Beach, FL 33064  
 954-633-4692



**Rational Analysis: Worst case is - 16 (Chassis 5) 115-7/8" x 63-3/8" x 57-3/8"**

Design Pressures complying to FBC Building 1620.6 (FHVHZ):

V = 186 mph (Risk Cat. III/IV), For Exp. Cat. "D" and Z = 65 ft, Kz = 1.33, Kzt = 1.0, Kd = 0.90  
Qz = .00256KzKztKdV<sup>2</sup> = 106.0 psf

Lateral Wind Pressure = WL = Qz(3.1) = 328.64 psf

Uplift Wind Pressure = UL = Qz(1.5) = 159.02 psf

Factoring in the required Load Combination factor (0.6):

Design Lateral Pressure = WL(0.6) = 197.2 psf  
Design Uplift Pressure = UL(0.6) = 95.4 psf

Since positive pressure acts toward the surface being considered and negative pressure acts away, only the uplift pressure will remove a panel from the machine. The design lateral pressure which is considered to act toward the windward surface is recognized to be a combination of the pressures acting on the windward and leeward surfaces. Wall pressure coefficients from ASCE7-10, Chapter 27, Figure 27.4-1 may be used to distribute the Design Lateral Pressure into positive and negative components acting on the windward and leeward surfaces, respectively.

L/B = 63.375/115.875 = 0.55 for wind on long (115-7/8") side  
L/B = 115.875/63.375 = 1.83 for wind on short (63-3/8") side

Worst case positive pressure coefficient is 0.8 for windward wall which has a corresponding negative pressure coefficient of 0.5 on the leeward wall. The worst case negative pressure coefficient is 0.7 for the sidewall (side parallel to wind). Since the windward and leeward wall pressures act in the same direction, the distributed pressures are computed as follows:

Lateral Positive Design Pressure = 197.18 (0.8) / (0.8 + 0.5) = 121.34 lb/ft<sup>2</sup> (Worst Case Positive)  
Lateral Negative Design Pressure = 197.18 (0.5) / (0.8 + 0.5) = 75.84 lb/ft<sup>2</sup>

Sidewall Negative Design Pressure = 197.18 (0.7) / (0.8 + 0.5) = 106.17 lb/ft<sup>2</sup> (Worst Case Negative)

22, 20, and 18 ga. panels and columns are fastened together and to 16 ga. base rails using #10 serrated washer head self tapping screws having 0.425" head diameter, 0.19" nominal diameter, and 0.14 minor diameter. These screws are expected to exhibit the following properties based upon ICC-ES Report ESR-2196:

Pullout Strength in 22 ga. = 306 lbs (ultimate)

Pullout Strength of 22 ga. = 828 lbs (ultimate)

Shear Strength in 22 ga. = 684 lbs (ultimate)

Pullout Strength in 18 ga. = 450 lbs (ultimate)

Shear Strength in 18 ga. = 684 lbs (ultimate)

Shear Strength in 16 ga. = 927 lbs (ultimate)

**For Top Panel Assembly (50TM500066 and 50TM500065 joined using 50TM500359 and 12 screws):**

114.4" x 61.6" draw formed 20 ga. assembly, anchored at edges and through top, to 16 ga. center panel and 18 ga. control box. Worst case portion is over air handler section since condenser section has (3) large holes in the top causing internal and external pressure to be equal. For portion tributary to air handling section:

A = 61.61(55.41)/12(12) = 23.70 sqft

Load = 23.70 (95.41) = 2261.9 lbs

For outside edge (9 screws, all in shear through 20 ga. top panel into 22 ga. indoor panel and corner posts):  
Screw Load = 2261.9/2(9) = 125.7 lbs

Safety Factor = 684/125.7 = 5.4 OK

For inside edge (8 screws in tension through 20 ga. top panel into 16 ga. center panel and 4 screws in shear through top panel into 22 ga. center posts):

Screw Load = 2261.9/2(12) = 94.2 lbs

Safety Factor = 684/94.2 = 7.3

OK for Components and Cladding

**For Inside Panel (50TM500063):**

61.5" x 53.42" draw formed 22 ga. panel anchored at edges with 7 screws through top panel into face at top, 6 screws each vertical edge through flange perpendicular to face, and 6 screws at 7/16 inch above bottom edge through panel into base rail, and 5 screws between supply and return openings into stiffener (50TM500058) fastened to condensing coil.

A = 61.5(53.42)/12(12) = 22.81 sqft

Load = 22.81(106.17) = 2422.2 lbs

Screw Load = 2422.2/2(6+6) = 100.93 lbs

Safety Factor = 450/100.93 = 4.5

OK for Components and Cladding

**For Access Panels (50TM500062):**

53.30" x 25.61" draw formed 22 ga. panel anchored with 3 screws through top face each vertical side, 2 screws through face at bottom edge into 16 ga. base rail, and top edge fits inside top panel (trapped).

A = 53.30(25.61)/12(12) = 9.48 sqft

Load = 9.48(106.17) = 1006.4 lbs

Screw Load = 1006.4/2(2 + 3) = 100.64 lbs

Safety Factor = 306/100.64 = 3.0

OK for Components and Cladding

**For Access Panel Assembly (50TM500086 and 50TM500061):**

53.0" x 53.30" assembly of draw formed 20 ga. panels anchored with (3) screws through face each vertical side, (5) screws through face at bottom edge into 16 ga. base rail, and top edge fits inside top panel (trapped).

A = 53.0(53.30)/12(12) = 19.62 sqft

Load = 19.62(106.17) = 2082.8 lbs

Screw Load = 2082.8/2(5+3) = 130.17 lbs

Safety Factor = 306/130.17 = 2.4

OK for Components and Cladding

Remaining panels are trivial cases of the above due to greater fastener quantity or having openings that limit negative pressure effects.

**For connection of upper frame and panels to base rails:**

16 screws each long side fasten frame posts and 22 ga. (min) panels to the long 16 ga. base rails. 6 screws fasten inside panel to short base rail at air handler end. Opposite end is louvered and has a large opening in the top and mesh over cooling coils.

Lateral Wind Area = AL = 114.35(53.625)/12(12) = 42.58 sqft

Lateral Design Load = 42.58(197.18) = 8296.6 lbs

Overturning Moment = 8396.6(53.625)/2 = 22513.4 in-lb

Uplift Wind Area = AU = 114.35(61.61)/12(12) = 48.92 sqft

Uplift Design Load = 48.92(95.41) = 4667.9 lbs

Uplift Moment = 4667.9(61.61)/2 = 14379.4 in-lb

Screw Load = (22513.4 + 14379.4)/16(61.61) = 374.3 lbs (shear)

Safety Factor = 927/374.3 = 2.5 OK for Components and Cladding

Unit itself will withstand wind loads imposed by 197.18 psf lateral and 95.41 psf uplift design pressures provided the 16 ga. galvanized base rails are properly fastened to a suitable slab, stand, curb, curb adapter, or other suitable mounting arrangement and all factory supplied assembly fasteners are in place.

**For connection of unit base rails to properly designed curb, metal stand, or structural concrete (by others):**

Lateral Wind Area = AL = 115.875(57.375)/12(12) = 46.17 sqft

Lateral Design Load = 346.17(197.18) = 9103.6 lbs

Overturning Moment = 9103.6(57.375)/2 = 26115.9 in-lb

Uplift Wind Area = AU = 115.875(63.375)/12(12) = 51.00 sqft

Uplift Design Load = 51.00(95.41) = 4882.6 lbs

Uplift Moment = 4882.6(63.375)/2 = 12936.9 in-lb

**For connection of 16 ga. (min) straps, clips, or brackets spaced 28" min apart to unit base rails on long sides Using 1/4" (#14) self-drilling screws:**

Pullout Strength in 16 ga. = 573 lbs (ultimate)  
Shear Strength in 16 ga. = 1389 lbs (ultimate)

Using (3) screws per strap, clip, or bracket, with (4) straps, clips, or brackets each long side:  
Screw Load = (26115.9 + 12936.9)/3(4)(63.375) = 513.5 lbs (shear) at base rail outer surface  
Safety Factor = 1389/513.5 = 2.7  
OK for Components and Cladding

**For (4) Z-Brackets each long side similar to Micromel design but modified to eliminate hidden structural fasteners anchored to 18 ga. (min) curb (by others):**

Shear Strength in 18 ga. = 1218 lbs (ultimate)

Screw Load = (26115.9 + 12936.9)/3(4)(53.81) = 604.8 lbs (shear) at curb inside surface  
Safety Factor = 1218/604.8 = 2.0  
OK for Components and Cladding

**For quantity (4) angle clips 3.25" wide x 2" x 2-1/2", 16 ga. (min), spaced 28" (min) on-center each long side:**

Anchor Load = (26115.9 + 12936.9)/4(64.125) = 1522.6 lbs (tension)

Anchor Load = 9103.6/8 = 1138.0 lbs (shear) at 3/4" beyond base rail outer surface

**For 3/8" SAE Gr. 5 bolts with nuts and washers to steel (by others):**

Safety Factor = 3720/1522.6 = 2.4 (tension)

Safety Factor = 1937/1138.0 = 1.7 (shear)

OK

OK


**For 3/8" Powers Wedge-Bolt + anchors with 2-1/8" (min) embedment into 2000 psi (min) concrete (by others), 4" (min) thick, 2-3/4" (min) edge distance, and 2-1/2" (min) spacing:**

Safety Factor = 3000/1522.6 = 2.0 (tension)

Safety Factor = 3100/1138.0 = 2.7 (shear)

OK

OK



Job No: Chassis 5  
Date: 1-08-16  
Created by: CORE

Job No: Bryant RTUs  
Title: Model List and Details

BRYANT Chassis 6, 7, 8 & 9:  
Models:

580J/558J - size 17 (min) through size 30 (max)  
548J - size 17 (min) through size 24 (max)  
581J/551J - size 17 (min) through size 28 (max)

Each condenser unit listed above conforms to the Florida Building Code 6th Edition (2017) requirements for installation including High Velocity Hurricane Zone (HVHZ), R Category III/IV (V = 186 MPH), exposure category "D", and installation height up to a including 65 feet above grade.

Worst Case is -26 (Chassis 9) 157-3/4" x 86-3/8" x 57-3/8"




### ALLOWABLE DESIGN PRESSURES FOR THE UNIT ITSELF:

Design Lateral Pressure = 197.2 psf

Design Uplift Pressure = 95.4 psf

Unit itself will withstand wind loads imposed by 197.2 psf lateral and 95.4 psf uplift design pressures, provided the 16 GA. galvanized base rails are fastened to a properly designed concrete slab, metal stand, curb, curb adapter, or other suitable mounting arrangement and all factory supplied assembly fasteners are in place.

QTY. 4-TEK .25-6.00  
GALVANIZED SHEETMETAL  
S.D. SCREWS AND WASHERS  
PER Z-BRACKET, (10) BRACKETS



**GALVANIZED STEEL, 16 GA.**

SECOND-BACKSET  
INSIDE CURB PRIOR T  
ROOFTOP INSTALL

## ROOFTOP BASE PAI

SEAL STRIP (BY OTHERS)  
2X .25 X 1.00 (SUPPLIED)

1.56 APPROX

—4X .25 X 6.00 (SUPPLIED)

## —ROOF CURB WOOD NAILER

—ROOFTOP BASE RAIL

ROOF CURE  
(BY OTHERS)

DETAIL C  
SCALE 1:4

(SUPPLIED)

QTY. 2- TEK .25-1.00  
GALVANIZED SHEETMETAL  
S.D. SCREWS AND WASHERS  
PER Z-BRACKET, (10) BRACKETS  
PRIOR TO SEAL STRIP INSTALL

Job No:

### Chassis 6, 7, 8 & 9

**Data:**

2-11-16

Created by:

## CORE

Job No:

## Bryant RTUs

**Title:**

## Model List and Details

AUG 10 2018

File # 75-10000-10000  
75-10000-10000  
Bldg. 3, Suite 220  
Prado Beach, FL 33504  
954-555-1630

**Rational Analysis: Worst case is - 24 (Chassis 9) 157-3/4" x 86-3/8" x 57-3/8"**

Design Pressures complying to FBC Building 1620.6 (HVHZ):

V = 186 mph (Risk Cat. II/IV), For Exp.Cat. "D" and Z = 65 ft, Kz = 1.33, Kzt = 1.0, Kd = 0.90

Qz = .00256KzKztKdV2 = 106.0 psf

Using 1620.6,

Lateral Wind Pressure = WL = qz(3.1) = 328.6 psf

Uplift Wind Pressure = UL = qz(1.5) = 159.0 psf

Factoring in the required Load Combination factor (0.6):

Design Lateral Pressure = WL(0.6) = 197.2 psf

Design Uplift Pressure = UL(0.6) = 95.4 psf

Since positive pressure acts toward the surface being considered and negative pressure acts away, only the uplift pressure will remove a panel from the machine. The design lateral pressure which is considered to act toward the windward surface is recognized to be a combination of the pressures acting on the windward and leeward surfaces. Wall pressure coefficients from ASCE7-10, Chapter 27, Figure 27.4-1 may be used to distribute the Design Lateral Pressure into positive and negative components acting on the windward and leeward surfaces, respectively.

L/B = 86.375/157.75 = 0.55 for wind on long (157-3/4") side  
L/B = 157.75/86.375 = 1.83 for wind on short (86-3/8") side

Worst case positive pressure coefficient is 0.8 for windward wall which has a corresponding negative pressure coefficient of 0.5 on the leeward wall. The worst case negative pressure coefficient is 0.7 for the sidewall (side parallel to wind). Since the windward and leeward wall pressures act in the same direction, the distributed pressures are computed as follows:

Lateral Positive Design Pressure = 197.18 (0.8) / (0.8 + 0.5) = 121.34 lb/ft2 (Worst Case Positive)

Lateral Negative Design Pressure = 197.18 (0.5) / (0.8 + 0.5) = 75.84 lb/ft2

Sidewall Negative Design Pressure = 197.18 (0.7) / (0.8 + 0.5) = 106.17 lb/ft2 (Worst Case Negative)

22, 20, and 18 ga. panels and columns are fastened together and to 16 ga. base rails using #10 serrated washer head self tapping screws having 0.425" head diameter, 0.19" nominal diameter, and 0.14 minor diameter. These screws are expected to exhibit the following properties based upon ICC-ES Report ESR-2196:

Pullout Strength in 22 ga. = 306 lbs (ultimate) Pullout Strength in 20 ga. = 351 lbs (ultimate)

Pullover Strength of 22 ga. = 828 lbs (ultimate) Pullover Strength of 20 ga. = 993 lbs (ultimate)

Shear Strength in 22 ga. = 684 lbs (ultimate) Shear Strength in 20 ga. = 684 lbs (ultimate)

Pullout Strength in 18 ga. = 450 lbs (ultimate)

Shear Strength in 16 ga. = 927 lbs (ultimate)

**For Top Panel Assembly (50HE500275 and 50HE500276 joined using 6 screws):**

85.0" x 82.5" draw formed 20 ga. assembly anchored at edges and through top to 16 ga. center panel, 18 ga. end panel assembly, 20 ga. side panels, and 18 ga. control box. This portion is over air handler section and is worst case since condenser section has three large holes in the top causing internal and external pressure to be equal.

A = 85.0(82.5)/12(12) = 48.70 sqft

Load = 48.70 (95.41) = 4646.3 lbs

For 8 (min) screws each 85.0" side into 18 ga. (min) panels and 12 screws each 82.5" side into 20 ga. (min) side panels:

Screw Load = 4646.3/2(8 + 12) = 116.2 lbs

Safety Factor = 684/116.2 = 5.9

OK for Components and Cladding

**For End Panel Assembly (50HE500719 and 50HE500762 joined together using 7 screws):**

73.0" x 53.5" draw formed 18 ga. panel anchored at edges with 5 screws through top panel into face at top, 5 screws each vertical edge face into 22 ga. (min) corner posts, and 5 screws at 3/8" inch above bottom edge through panel into base rail.

A = 73.0(53.5)/12(12) = 27.12 sqft

Load = 27.12(106.17) = 2879.5 lbs

Screw Load = 2879.5/2(5+5) = 143.97 lbs

Safety Factor = 306/143.97 = 2.1

OK for Components and Cladding

**For Access Panel (50HE500423):**

53.30" x 25.61" draw formed 22 ga. panel anchored with 3 screws through face each vertical side, 2 screws through face at bottom edge into 16 ga. base rail, and top edge fits inside top panel (trapped).

A = 53.5(26.4)/12(12) = 9.81 sqft

Load = 9.81(106.17) = 1041.4 lbs

Screw Load = 1041.4/2(3 + 3) = 86.78 lbs

Safety Factor = 306/86.78 = 3.5

OK for Components and Cladding

Remaining panels are trivial cases of the above due to greater fastener quantity or having openings that limit negative pressure effects.

**For connection of upper frame and panels to base rails:**

12 screws each long side fasten frame posts and 20 ga. (min) panels to the long 16 ga. base rails. 8 screws fasten inside panel to short base rail at air handler end. Opposite end is louvered and has a large opening in the top and mesh over cooling coils.

Lateral Wind Area = AL = 156.0(53.625)/12(12) = 58.09 sqft

Lateral Design Load = 58.09(197.18) = 11454.9 lbs

Overturning Moment = 11454.9(53.625)/2 = 307135 in-lb

Uplift Wind Area = AU = 156.0(85.0)/12(12) = 92.08 sqft

Uplift Design Load = 92.08(95.41) = 8785.7 lbs

Uplift Moment = 8785.7(85.0)/2 = 373391 in-lb

Screw Load = (307135 + 373391)/(16 + 8)(85.0) = 333.6 lbs (shear)

Safety Factor = 927/333.6 = 2.8

OK for Components and Cladding

Unit itself will withstand wind loads imposed by 197.18 psf lateral and 95.41 psf uplift design pressures provided the 16 gage galvanized base rails are properly fastened to a suitable slab, stand, curb, curb adapter, or other suitable mounting arrangement and all factory supplied assembly fasteners are in place.

**For connection of unit base rails to properly designed curb, metal stand, or structural concrete (by others):**

Lateral Wind Area = AL = 157.75(57.375)/12(12) = 62.85 sqft

Lateral Design Load = 62.85(197.18) = 12393.5 lbs

Overturning Moment = 12393.5(57.375)/2 = 355537 in-lb

Uplift Wind Area = AU = 157.75(86.375)/12(12) = 94.6 sqft

Uplift Design Load = 94.6(95.41) - 0.6(2248) = 7679.1 lbs

Uplift Moment = 7679.1(76.875)/2 = 295167 in-lb

**For connection of 16 ga. (min) straps, clips, or brackets spaced 32" (min) apart to unit base rails Using 1/4" (#14) self-drilling screws:**

Pullout Strength in 16 ga. = 573 lbs (ultimate)  
Shear Strength in 16 ga. = 1389 lbs (ultimate)

Using (3) screws per strap, clip, or bracket, with 5 straps, clips, or brackets each long side:

Screw Load = (355537 + 295167)/3(5)(86.375) = 502.3 lbs (shear) at base rail outer surface

Safety Factor = 1389/502.3 = 2.8

OK for Components and Cladding

**For (5) Z-Brackets each long side similar to Micromet design but modified to eliminate hidden structural fasteners anchored to 18 ga. (min) curb (by others):**

Shear Strength in 18 ga. = 1218 lbs (ultimate)

Screw Load = (355537 + 295167)/5(87.125) = 564.3 lbs (shear) at curb inside surface  
Safety Factor = 1218/564.3 = 2.2

OK for Components and Cladding

**For quantity (5) angle clips 3.25" wide x 2" x 2-1/2", 16 ga. (min), spaced 32" (min), on-center each long side:**

Anchor Load = (355537 + 295167)/5(87.125) = 1493.8 lbs (tension)  
Anchor Load = 12393.5/10 = 1239.4 lbs (shear) at 3/4" beyond base rail outer surface

**For 3/8" SAE Gr. 5 bolts with nuts and washers to steel (by others):**

Safety Factor = 3720/1493.8 = 2.5 (tension)

Safety Factor = 1937/1239.4 = 1.6 (shear)

OK

OK


**For 3/8" Powers Wedge-Bolt + anchors with 2-1/8" (min) embedment into 2000 psi (min) concrete (by others), 4" (min) thick, 2-3/4" (min) edge distance, and 2-1/2" (min) spacing:**

Safety Factor = 3000/1493.8 = 2.0 (tension)

Safety Factor = 3100/1239.4 = 2.5 (shear)

OK

OK



Bryant RTUs  
Model List and Details

Job No:	Chassis 6, 7, 8 & 9
Date:	1-08-16
Created by:	CORE