

Design Uplift Pressure = UL(0.6) = 95.4 psfLateral Wind Pressure = WL = qz(3.1) = 328.6 psfUplift Wind Pressure = UL = qz(1.5) = 159.0 psfFactoring in the required Load Combination factor (0.6): Design Lateral Pressure = WL(0.6) = 197.2 psfDesign Pressures complying to FBC Building 1620.6 (HVHZ): V = 186 mph (Risk Cat. III/IV), For Exp.Cat. "D" and Z = 65 ft, $Qz = .00256K_ZK_ZtKdV2 = 106.0$ psf Using 1620.6, Rational Analysis: Worst case is - 24 (Chassis 9) 157-3/4" x 86-3/8" x 57-3/8" Kz = 1.33, Kzt = 1.0, Kd = 0.90

U

Since positive pressure acts toward the surface being considered and negative pressure acts away, only the uplift pressure will remove a panel from the machine. The design lateral pressure which is considered to act toward the windward surface is recognized to be a combination of the pressures acting on the windward and leeward surfaces. Wall pressure coefficients from ASCE7-10, Chapter 27, Figure 27.4-1 may be used to distribute the Design Lateral Pressure into positive and negative componenets acting on the windward and leeward surfaces, respectively.

O

Shear Strength in 16 ga. = 927 lbs (ultimate)

condenser section has three large holes in the top causing internal and external pressure to be equal. For Top Panel Assembly (50HE500275 and 50HE500276 joined using 6 screws): 85.0" x 82.5" draw formed 20 ga. assembly anchored at edges and through top to 16 ga. center panel, 18 ga. end panel assembly, 20 ga. side panels, and 18 ga. control box. This portion is over air handler section and is worst case since

œ

For 8 (min) screws each 85.0" side into 18 ga. (min) panels and 12 screws each 82.5" side into 20 ga. (min) side panels: Screw Load = 4646.3/2(8 + 12) = 116.2 lbs

Safety Factor = 684/116.2 = 5.9

OK for Components and Cladding OK for Components and Cladding

Sql

Load = 9.81(106.17) = 1041.4 lbs Screw Load = 1041.4/2(3 + 3) = 86.78Safety Factor = 306/86.78 = 3.5A = 53.5(26.4)/12(12) = 9.81 sqft

Remaining panels are trivial cases of the above due to pressure effects. greater fastener quantity or having openings that limit negative

L/B = 86.375/157.75 = 0.55 for wind on long (157-3/4") side L/B = 157.75/86.375 = 1.83 for wind on short (86-3/8") side

Worst case positive pressure coefficient is 0.8 for windward wall which has a corresponding negative pressure coefficient of 0.5 on the leeward wall. The worst case negative pressure coefficient is 0.7 for the sidewall (side parallel to wind). Since the windward and leeward wall pressures act in the same direction, the distibuted pressures are computed as follows:

Lateral Positive Design Pressure = 197.18 (0.8) / (0.8 + 0.5) = 121.34 lb/ft2 (Worst Case Positve) Lateral Negative Design Pressure = 197.18 (0.5) / (0.8 + 0.5) = 75.84 lb/ft2 (Worst Case Negative) Sidewall Negative Design Pressure = 197.18 (0.7) / (0.8 + 0.5) = 106.17 lb/ft2 (Worst Case Negative)

22, 20, and 18 ga. panels and columns are fastened together and to 16 ga. base rails using #10 serrated washer head self tapping screws having 0.425" head diameter, 0.19" nominal diameter, and 0.14 minor diameter. These screws are expected to exhibit the following properties based upon ICC-ES Report ESR-2196:

Pullout Strength in 22 ga. = 306 lbs (ultimate) Pullout Strength in 20 ga. = 351 lbs (ultimate) Pullover Strength of 22 ga. = 828 lbs (ultimate) Pullover Strength of 20 ga. = 993 lbs (ultimate) Shear Strength in 22 ga. = 684 lbs (ultimate) Shear Strength in 20 ga. = 684 lbs (ultimate) Pullout Strength in 18 ga. = 450 lbs (ultimate)

A = 85.0(82.5)/12(12) = 48.70 sqftLoad = 48.70 (95.41) = 4646.3 lbs

For End Panel Assembly (50HE500719 and 50HE500762 joined together using 7 screws):
73.0" x 53.5" draw formed 18 ga. panel anchored at edges with 5 screws through top panel into face at top, 5 screws each vertical edge face into 22 ga. (min) corner posts, and 5 screws at 3/8" inch above bottom edge through panel into base rail.

A = 73.0(53.5)/12(12) = 27.12 sqft Load = 27.12(106.17) = 2879.5 lbs Screw Load = 2879.5/2(5+5) = 143.97 Safety Factor = 306/143.97 = 2.1

For Access Panel (50HE500423): 53.30" x 25.61" draw formed 22 ga. panel anchored with 3 screws through face each vertical side, 2 screws through face at bottom edge into 16 ga. base rail, and top edge fits inside top panel (trapped). OK for Components and Cladding

OK for Components and Cladding

For connection of upper frame and panels to base rails:
12 screws each long side fasten frame posts and 20 ga. (min) panels to the long 16 ga. base rails. 8 screws fasten inside panel to short base rail at air handler end. Opposite end is louvered and has a large opening in

2

Overturning Moment = 11454.9(53.625)/2 = 307135 in-lb Lateral Wind Area = AL = 156.0(53.625)/12(12) = 58.09 sqftLateral Design Load = 58.09(197.18) = 11454.9 lbs

Uplift Wind Area = AU = 156.0(85.0)/12(12) = 92.08 sqft Uplift Design Load = 92.08(95.41) = 8785.7 lbs Uplift Moment = 8785.7(85.0)/2 = 373391 in-lb

Screw Load = (307135 + 373391)/(16 + 8)(85.0) = 333.6 lbs (shear) Safety Factor = 927/333.6 = 2.8 OK for for Components and Cladding

Unit itself will withstand wind loads imposed by 197.18 psf lateral and 95.41 psf uplift design pressures provided the 16 gage galvanized base rails are properly fastened to a suitable slab, stand, curb, curb adapter, or other suitable mounting arrangement and all factory supplied assembly fasteners are in place. Unit itself will withstand wind loads imposed by 197.18 psf lateral

For connection of unit base rails to properly designed curb, metal stand, or structural concrete

Lateral Design Load = 62.85(197.18) = 12393.5 lbs Overturning Moment = 12393.5(57.375)/2 = 355537 in-lb Uplift Wind Area = AU = 157.75(86.375)/12(12) = 94.6 sqft Uplift Design Load = 94.6(95.41) - 0.6(2248) = 7679.1 lbs Uplift Moment = 7679.1(76.875)/2 = 295167 in-lb Lateral Wind Area = AL = 157.75(57.375)/12(12) = 62.85 sqft

 \cap

For connection of 16 ga. (min) straps, clips, or brackets spaced 32" (min) apart to unit base rails Using 1/4" (#14) self-drilling screws:

Pullout Strength in 16 ga. = 573 lbs (ultimate) Shear Strength in 16 ga. = 1389 lbs (ultimate)

Using (3) screws per strap, clip, or bracket, with 5 straps, clips, or brackets each long side:

Screw Load = (355537 + 295167)/3(5)(86.375) = 502.3 lbs (shear) at base rail outer surface

Safety Factor = 1389/502.3 = 2.8

OK for Components and Cladding

For (5) Z-Brackets each long side similar to Micrometl design but structural fasteners anchored to 18 ga. (min) curb (by others): modified to eliminate hidden

Shear Strength in 18 ga. = 1218 lbs (ultimate)

Screw Load = (355537 + 295167)/3(5)(76.875) = 564.3 lbs (shear) at Safety Factor = 1218/564.3 = 2.2 OK for (t curb inside surface Components and Cladding

For quantity (5) angle clips 3.25" wide x 2" x 2-1/2", 16 ga. (min), paced 32" (min), on-center

Anchor Load = (355537 + 295167)/5(87.125) = 1493.8 lbs (tension) Anchor Load = 12393.5/10 = 1239.4 lbs (shear) at 3/4" beyond base

For 3/8" SAE Gr. 5 bolts with nuts and washers to steel (by others)
Safety Factor = 3720/1493.8 = 2.5 (tension)
OK
Safety Factor = 1937/1239.4 = 1.6 (shear)
OK ail outer surface

For 3/8" Powers Wedge-Bolt + anchors with concrete (by others), 4" (min) thick, 2-3/4" (n Safety Factor = 3000/1493.8 = 2.0 (tension) Safety Factor = 3100/1239.4 = 2.5 (shear) " (min) edge distance, s OK OK 2-1/8" (min) embedment into 2000 psi (min) min) edge distance, and 2-1/2" (min) spacing:

V

Job No: Job No: Chassis 6, 7, 8 & 9 Bryant RTUs Data: 1-08-16 Created by: Model List and Details CORE

3, Rea